


SE 1/4, SEC. 33, T. 25N., R. 44E., W.M.
 SW 1/4, SEC. 34, T. 25N., R. 44E., W.M.
 NE 1/4, SEC. 4, T. 24N., R. 44E., W.M.



IMPROVEMENT PLANS PAINTED HILLS PRD - GUSTIN DITCH LOCATED IN A PORTION OF SE 1/4, SEC. 33, T. 25N., R. 44E., W.M. SPOKANE COUNTY, WA




LOCATION MAP

SHEET INDEX

CO.0	COVER SHEET
CO.1	GENERAL NOTES
C1.0	TOPOGRAPHIC SURVEY
C4.0	GRADING PLAN
C5.0	TRIANGLE POND PLAN
C9.0	EROSION CONTROL/SWPPP PLAN
C9.1	SWPPP NOTES
C9.2	SWPPP BMPs
C9.3	SWPPP BMPs

NOTE:
 CONSTRUCTION OF EVERY DRYWELL AND INFILTRATION GALLERY, INCLUDING FABRIC AND DRAIN ROCK, SHALL BE OBSERVED BY THE ON-SITE INSPECTOR TO CONFIRM THAT THEY MEET THE DESIGN DETAILS AND SPECIFICATIONS. DRYWELLS/GALLERIES NOT OBSERVED SHALL HAVE THEIR PERFORMANCE VERIFIED BY A FULL-SCALE DRYWELL TEST.



SITE PLAN

SCALE: 1" = 100'

LEGEND

EXISTING	DESCRIPTION	PROPOSED
---	ROADWAY CENTER LINE	---
---	RIGHT OF WAY LINE	---
---	PROPERTY LINE	---
---	EASEMENT LINE	---
-x-x-	FENCE	-x-x-
---	CURB	---
---	PAVEMENT	---
---	GRAVEL	---
---	CONCRETE	---
	BUILDINGS & STRUCTURES	
---	MONUMENT	---
SEWER		
-S-S-S-	SANITARY SEWER	-S-S-S-
-S-S-S-	MANHOLE	-S-S-S-
-S-S-S-	CLEANOUT	-S-S-S-
-S-S-S-	SEWER SERVICE	-S-S-S-
WATER		
-W-W-W-	WATER LINE	-W-W-W-
-W-W-W-	VALVE	-W-W-W-
-W-W-W-	FIRE HYDRANT	-W-W-W-
-W-W-W-	SERVICE	-W-W-W-
-W-W-W-	WATER METER	-W-W-W-
-W-W-W-	BLOWOFF	-W-W-W-
-W-W-W-	AIR VACUUM RELIEF STATION	-W-W-W-
DRAINAGE		
-D-D-D-	DRAINAGE LINE	-D-D-D-
-D-D-D-	MANHOLE	-D-D-D-
-D-D-D-	DRYWELL	-D-D-D-
-D-D-D-	CATCH BASIN	-D-D-D-
-D-D-D-	DITCH	-D-D-D-
GAS		
-G-G-G-	GAS LINE	-G-G-G-
-G-G-G-	VALVE	-G-G-G-
-G-G-G-	METER	-G-G-G-
TELE-POWER		
-BT-BT-BT-	BURIED TELEPHONE	-BT-BT-BT-
-BT-BT-BT-	POWER OR TELEPHONE POLE	-BT-BT-BT-
-BP-BP-BP-	BURIED POWER	-BP-BP-BP-
-BP-BP-BP-	TRANSFORMER PAD	-BP-BP-BP-
-BP-BP-BP-	TELEPHONE RISER	-BP-BP-BP-
-BP-BP-BP-	TELEPHONE VAULT	-BP-BP-BP-
-OP-OP-OP-	OVERHEAD POWER	-OP-OP-OP-
-OP-OP-OP-	GUY ANCHOR	-OP-OP-OP-
-OP-OP-OP-	POWER VAULT	-OP-OP-OP-
-OP-OP-OP-	LIGHT POLE	-OP-OP-OP-

ABBREVIATIONS

ACT. LEN.	ACTUAL LENGTH	GB	GRADE BREAK	PRC	POINT OF REVERSE CURVE
BCR	BEGINNING OF CURVE RADIUS	FT./FT.	FEET PER FOOT	PT	POINT OF TANGENCY
BDRY.	BOUNDARY	HYD.	HYDRANT	RD	RIM ELEVATION
CO.	SEWER CLEANOUT	I.E.	INVERT ELEVATION	RT.	ROAD
CSTC	CRUSHED SURFACE	LN.	LANE	SI	STREET INTERSECTION
	TOP COURSE	LT.	LEFT	SS	SANITARY SEWER
CT.	COURT	MH	MANHOLE	STA.	STATION
DIA.	DIAMETER	MCR	MIDDLE OF CURVE RADIUS	STA. LEN.	STATION LENGTH
ECR	END OF CURVE RADIUS	PC	POINT OF CURVATURE	TG	TOP OF GRATE
EXIST.	EXISTING	PET.	PETROLEUM	TC	TOP OF CURB
G	GRADE	PI	POINT OF INTERSECTION		

PERMIT SPECIALIST
 CITY OF SPOKANE VALLEY
 PERMIT CENTER
 11707 E SPRAGUE AVE
 SPOKANE, WA 99206
 PHONE: 720-5324
 CONTACT: JOHN JOHNSON

DEV. CONST. INSP.
 CITY OF SPOKANE VALLEY
 11707 E SPRAGUE AVE
 SPOKANE, WA 99206
 PHONE: 720-5324
 CONTACT: JOHN JOHNSON

CABLE
 COMCAST BROADBAND
 1717 E BUCKEYE AVE
 SPOKANE, WA 99207
 PHONE: 755-4717
 CONTACT: BRYAN RICHARDSON

SEWER
 SPOKANE COUNTY UTILITIES
 1026 W BROADWAY AVE
 SPOKANE, WA 99260
 PHONE: 477-7180
 CONTACT: CHRIS KNUDSON

HEALTH
 SPOKANE REGIONAL HEALTH
 1101 W COLLEGE AVE
 SPOKANE, WA 99260
 PHONE: 324-1578
 CONTACT: PAUL SAVAGE

SOLID WASTE
 WASTE MANAGEMENT
 PHONE:
 1-866-909-4458

WATER
 SPOKANE COUNTY WATER DISTRICT #3
 1225 N YARDLEY ST
 SPOKANE, WA 99212
 PHONE: 536-0121
 CONTACT: TY WICK

GAS
 AVISTA UTILITIES
 1411 E MISSION AVE
 SPOKANE, WA 99220
 PHONE: 495-8610
 CONTACT: KEN CARLSON

INSPECTION
 I.P.E.C.
 P. O. BOX 1566
 VERADALE, WA 99037
 PHONE: 209-2622
 CONTACT: PAUL T. NELSON, P.E.

FIRE
 SPOKANE VALLEY FIRE DEPT.
 2120 N WILBUR RD
 SPOKANE VALLEY, WA 99206
 PHONE: 928-1700
 CONTACT: TRACI HARVEY

TELEPHONE
 CENTURY LINK
 904 N COLUMBUS ST
 SPOKANE, WA 99224
 PHONE: 623-0305
 CONTACT: DEBORAH GEIST

SURVEYOR
 WHIPPLE CONSULTING ENGINEERS
 2528 N SULLIVAN RD
 SPOKANE VALLEY, WA 99216
 PHONE: 893-2617
 CONTACT: JON GORDON, P.L.S.

ROADWAYS
 CITY OF SPOKANE VALLEY
 11707 E SPRAGUE AVE
 SPOKANE VALLEY, WA 99206
 PHONE: 688-0228
 CONTACT: M. ALLEN

POWER
 INLAND POWER & LIGHT CO.
 10110 W HALLETT RD
 SPOKANE, WA 99224
 PHONE: 509-789-4291
 CONTACT: CONNIE NELSON

ENGINEERING
 WHIPPLE CONSULTING ENGINEERS
 2528 N SULLIVAN RD
 SPOKANE VALLEY, WA 99216
 PHONE: 893-2617
 CONTACT: TODD WHIPPLE, P.E.

OWNER
 BRYAN WALKER
 C/O NAI BLACK
 107 S HOWARD ST
 SPOKANE, WA 99201
 PHONE: 623-1000
 CONTACT: BRYAN WALKER

DEVELOPER APPROVAL _____ DATE _____


PLANS
 NOT APPROVED
 BY AGENCY

Spokane County Permit No.:

Floodplain-Grading-

City of Spokane Valley Permit No.:

SUB-2015-0001
 FPD-2016-
 EGR-201X-XXXX



10/13/16

NAVD - 88
 TBM S-5 OF THE SOUTH PONDEROSA SEWER PROJECT
 WITH AN ELEVATION OF 2005.87 (NAVD29) - 2009.67
 (NAVD88) WAS USED FOR THE VERTICAL DATUM FOR THIS MAP.

NO.	DATE	BY	REVISIONS
A	08/03/16	RMA	ORIGINAL PREPARATION

SCALE:
 HORIZONTAL:
 1" = 100'
 VERTICAL:
 N/A

PROJ #: 13-1166
DATE: 08/03/16
DRAWN: RMA
REVIEWED: TRW



**GUSTIN DITCH IMPROVEMENT PLANS
 COVER SHEET
 40TH AVENUE
 SPOKANE COUNTY, WA**

**SHEET
 CO.0**
 JOB NUMBER
 13-1166

WCE GENERAL NOTES

1. ALL MATERIALS, WORKMANSHIP, AND CONSTRUCTION OF SITE IMPROVEMENTS SHALL MEET OR EXCEED SITE WORK STANDARDS AND THE STANDARDS AND SPECIFICATIONS SET FORTH IN THE SPOKANE COUNTY REGULATIONS AND APPLICABLE STATE AND FEDERAL REGULATIONS, WHERE THERE IS CONFLICT BETWEEN THESE PLANS AND THE SPECIFICATIONS, OR ANY APPLICABLE STANDARDS, THE HIGHER QUALITY STANDARD SHALL APPLY. ALL WORK WITHIN PUBLIC R.O.W. OR EASEMENTS SHALL BE INSPECTED AND APPROVED BY THE SPOKANE COUNTY INSPECTOR. INSPECTION SERVICES AND CONSTRUCTION CERTIFICATION TO BE PROVIDED BY DESIGNEE OF PROJECT SPONSOR/OWNER.
2. THE CONTRACTOR IS SPECIFICALLY CAUTIONED THAT THE LOCATION AND/OR ELEVATION OF EXISTING UTILITIES, AS SHOWN ON THESE PLANS, IS BASED ON RECORDS OF THE VARIOUS UTILITY COMPANIES AND, WHERE POSSIBLE, MEASUREMENTS TAKEN IN THE FIELD. THE INFORMATION IS NOT TO BE RELIED UPON AS BEING EXACT OR COMPLETE. THE CONTRACTOR MUST CALL THE LOCAL UTILITY LOCATION CENTER AT LEAST 48 HOURS BEFORE ANY EXCAVATION TO REQUEST EXACT FIELD LOCATIONS OF EXISTING UTILITIES. THE CONTRACTOR SHALL VERIFY PERTINENT LOCATIONS AND ELEVATIONS, ESPECIALLY AT THE CONNECTION POINTS AND AT UTILITY CONFLICTS. IT SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR TO RELOCATE ALL EXISTING UTILITIES THAT CONFLICT WITH THE PROPOSED IMPROVEMENTS SHOWN ON THESE PLANS.
3. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS FROM ALL APPLICABLE AGENCIES. THE CONTRACTOR SHALL NOTIFY THE SPOKANE COUNTY INSPECTOR AT LEAST 48 HOURS PRIOR TO THE START OF ANY EARTH DISTURBING ACTIVITY OR CONSTRUCTION ON ANY AND ALL PUBLIC IMPROVEMENTS.
4. THE CONTRACTOR SHALL COORDINATE AND COOPERATE WITH THE SPOKANE COUNTY AND ALL UTILITY COMPANIES WITH REGARD TO RELOCATIONS OR ADJUSTMENTS OF EXISTING UTILITIES DURING CONSTRUCTION, TO ASSURE THAT THE WORK IS ACCOMPLISHED IN A TIMELY FASHION, AND WITH A MINIMUM DISRUPTION OF SERVICE. THE CONTRACTOR SHALL BE RESPONSIBLE FOR CONTACTING ALL PARTIES AFFECTED BY ANY DISRUPTION OF ANY UTILITY SERVICE.
5. THE CONTRACTOR SHALL HAVE ONE (1) SIGNED COPY OF THE APPROVED PLANS, ONE (1) COPY OF THE APPROPRIATE STANDARDS AND SPECIFICATIONS, AND ONE (1) COPY OF ANY PERMITS AND EXTENSION AGREEMENTS NEEDED FOR THE JOB ON-SITE AT ALL TIMES.
6. THE CONTRACTOR SHALL BE RESPONSIBLE FOR ALL ASPECTS OF SAFETY INCLUDING, BUT NOT LIMITED TO: EXCAVATION, TRENCHING, SHORING, TRAFFIC CONTROL, AND SECURITY.
7. IF, DURING THE CONSTRUCTION PROCESS, CONDITIONS ARE ENCOUNTERED BY THE CONTRACTOR, HIS SUBCONTRACTORS, OR OTHER AFFECTED PARTIES WHICH COULD INDICATE A SITUATION THAT IS NOT IDENTIFIED IN THE PLANS OR SPECIFICATIONS, THE CONTRACTOR SHALL CONTACT THE ENGINEER IMMEDIATELY.
8. ALL REFERENCES TO ANY PUBLISHED STANDARDS SHALL REFER TO THE LATEST REVISION OF SAID STANDARD, UNLESS SPECIFICALLY STATED OTHERWISE.
9. FOR WORK AFFECTING PUBLIC ROADWAYS OR IF REQUIRED BY THE SPOKANE COUNTY, THE CONTRACTOR SHALL SUBMIT A TRAFFIC CONTROL AND PHASING PLAN IN ACCORDANCE WITH M.U.T.C.D. FOR APPROVAL PRIOR TO ANY CONSTRUCTION ACTIVITIES WITHIN OR AFFECTING THE RIGHT-OF-WAY. THE CONTRACTOR SHALL BE RESPONSIBLE FOR PROVIDING ANY AND ALL TRAFFIC CONTROL DEVICES AS MAY BE REQUIRED BY SAID PLANS, PRIOR TO INSTALLATION. A PRECONSTRUCTION CONFERENCE SHALL BE HELD WITH THE SPOKANE COUNTY.
10. THE CONTRACTOR IS RESPONSIBLE FOR PROVIDING ALL LABOR AND MATERIALS NECESSARY FOR THE COMPLETION OF THE INTENDED IMPROVEMENTS SHOWN ON THESE DRAWINGS OR DESIGNATED TO BE PROVIDED, INSTALLED, CONSTRUCTED, REMOVED OR RELOCATED UNLESS SPECIFICALLY NOTED OTHERWISE.
11. PER AGENCY STANDARDS THE CONTRACTOR SHALL BE RESPONSIBLE FOR KEEPING ROADWAYS FREE AND CLEAR OF ALL CONSTRUCTION DEBRIS AND DIRT TRACKED FROM THE SITE.
12. THE CONTRACTOR SHALL BE RESPONSIBLE FOR RECORDING RECORD INFORMATION ON A SET OF RECORD DRAWINGS KEPT AT THE CONSTRUCTION SITE AND AVAILABLE TO THE SPOKANE COUNTY INSPECTOR AT ALL TIMES.
13. DIMENSIONS FOR LAYOUT AND CONSTRUCTION ARE NOT TO BE SCALED FROM ANY DRAWING. FOR ADDITIONAL INFORMATION CONTACT THE ENGINEER FOR CLARIFICATION AND NOTE ON THE RECORD DRAWINGS.
14. ALL EROSION AND SEDIMENT CONTROL (E.S.C.) MEASURES SHALL BE INSTALLED AT THE LIMITS OF CONSTRUCTION PRIOR TO GROUND DISTURBING ACTIVITY. ALL E.S.C. MEASURES SHALL BE MAINTAINED IN GOOD REPAIR BY THE CONTRACTOR UNTIL SUCH TIME AS THE ENTIRE DISTURBED AREAS ARE STABILIZED WITH HARD SURFACE OR LANDSCAPING.
15. THE CONTRACTOR SHALL SEQUENCE INSTALLATION OF UTILITIES IN SUCH A MANNER AS TO MINIMIZE POTENTIAL UTILITY CONFLICTS. IN GENERAL, STORM SEWER AND SANITARY SEWER SHOULD BE CONSTRUCTED PRIOR TO INSTALLATION OF WATER LINES AND DRY UTILITIES. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO COORDINATE ALL UTILITY RELOCATIONS CONSISTENT WITH THE CONTRACTORS SCHEDULE FOR THIS PROJECT, WHETHER SHOWN OR NOT SHOWN, AS IT RELATES TO THE CONSTRUCTION ACTIVITIES CONTEMPLATED IN THESE PLANS.
16. ALL WORK WITHIN THE PUBLIC RIGHT-OF-WAY IS SUBJECT TO THE JURISDICTION OF THE SPOKANE COUNTY ENGINEERING DEPARTMENT STANDARD DETAILS AND SPECIFICATIONS.
17. ALL CONSTRUCTION OPERATIONS, INCLUDING THE WARMING UP, REPAIR, ARRIVAL, DEPARTURE OR RUNNING OF TRUCKS, EARTH MOVING EQUIPMENT, CONSTRUCTION EQUIPMENT AND ANY OTHER ASSOCIATED EQUIPMENT SHALL GENERALLY BE LIMITED TO THE TIME PERIOD APPROVED BY THE SPOKANE COUNTY.
18. BASED ON REQUIREMENTS FROM SPOKANE COUNTY, THE ENGINEER OR HIS DESIGNEE SHALL PERFORM MATERIALS TESTING AND QUALITY CONTROL ON THE PROJECT AND SHALL SUBMIT COPIES OF DAILY REPORTS, TEST REPORTS, PROJECT CERTIFICATION AND RECORD DRAWINGS TO SPOKANE COUNTY ENGINEER.
19. NO REVISIONS SHALL BE MADE TO THESE PLANS WITHOUT APPROVAL OF THE SPOKANE COUNTY ENGINEERS AND NOTIFICATION OF THE ENGINEER OF RECORD.
20. ON-SITE GRADING SHALL BE IN ACCORDANCE WITH THE APPROVED GRADING PLAN AND E.S.C. PLAN. ANY IMPORT OR EXPORT OF MATERIAL SHALL BE FROM A PREAPPROVED SOURCE/DESTINATION AND COORDINATED WITH THE SPOKANE COUNTY DEPARTMENT OF BUILDING AND PLANNING AT 509-477-3675. GRADING ON THIS SITE OR ANY OTHER SITE MUST COMPLY WITH ALL DEVELOPMENT REGULATIONS INCLUDING, BUT NOT LIMITED TO, GRADING PERMITS, S.E.P.A. REVIEW, TIMBER HARVEST PERMITS, CRITICAL AREAS, FLOOD PLAINS, DESIGNATED DRAINAGE WAYS, ETC.
21. THE CONTRACTOR IS CAUTIONED THAT IT IS THE UNDERSTANDING OF THE OWNER AND THE ENGINEER THAT SHOULD A CONFLICT OR DISCREPANCY IN THESE PLANS, SPECIFICATIONS, GENERAL NOTES OR PLANS E.T.A.L. DETERMINED TO BE PART OF THE OVERALL PROJECT, INCLUDING BUT NOT LIMITED TO THE ARCHITECTURAL PLANS, MECHANICAL PLANS, ELECTRICAL PLANS, LANDSCAPE PLANS, GENERAL SPECIAL PROVISIONS, ETC., THAT WITHOUT WRITTEN CLARIFICATION FROM THE ENGINEER, OWNER OR OTHER PROFESSIONAL, DURING THE BIDDING PROCESS, THAT IN ALL INSTANCES THE CONTRACTOR WILL BE REQUIRED TO BID THE HIGHER STANDARD. FAILURE TO DO SO MAY RESULT IN THE HIGHER STANDARD BEING REQUIRED BY THE OWNER, ENGINEER OR OTHER PROFESSIONAL WITH NO CHANGE IN VALUE TO THE CONTRACT VIA CHANGE ORDER OR OTHER MECHANISM.
22. CONSTRUCTION OF EVERY DRYWELL, INCLUDING FABRIC AND DRAINROCK, SHALL BE OBSERVED BY THE ON-SITE INSPECTOR TO CONFIRM THAT IT MEETS THE DESIGN DETAILS AND SPECIFICATIONS. DRYWELLS NOT OBSERVED SHALL HAVE THEIR PERFORMANCE VERIFIED BY A FULL-SCALE DRYWELL TEST.
23. DURING CONSTRUCTION THE CONTRACTOR IS RESPONSIBLE TO COORDINATE ANY AND ALL INCONSISTENCIES BETWEEN THESE PLANS AND CONSTRUCTION STAKING. CONTRACTOR ASSUMES RESPONSIBILITY TO CONSTRUCT TO THESE PLANS IN LIEU OF FIELD STAKING. SHOULD INCONSISTENCIES BE APPARENT THE CONTRACTOR SHALL CONTACT THE ENGINEER, OWNER, AND SURVEYOR TO RECTIFY THE DISCREPANCY PRIOR TO CONSTRUCTION EFFORT BEING APPLIED.
24. FAIR HOUSING ACT – SAFE HARBORS FOR COMPLIANCE

WHIPPLE CONSULTING ENGINEERS, INC. FOR THE PROJECT CONTAINED WITHIN THESE PLANS HAS USED THE FOLLOWING SAFE HARBOR FOR ADA ACCESSIBILITY FOR THOSE ISSUES CONSIDERED SITE DEVELOPMENT ISSUES.

ICC/ANSI A117.1 (2003), ALONG WITH THE FAIR HOUSING ACT, HUD'S FAIR HOUSING ACT REGULATIONS, AND GUIDELINES.
25. ALL FIRE LINES MUST BE INSTALLED BY AN APPROVED LEVEL 'U' CONTRACTOR OR A LEVEL 3 FIRE PROTECTION CONTRACTOR.

SE 1/4, SEC.33, T.25N., R.44E., W.M.
 SW 1/4, SEC.34, T.25N., R.44E., W.M.
 NE 1/4, SEC. 4, T.24N., R.44E., W.M.

WCE GRADING NOTES

1. CONTOURS AND / OR ELEVATIONS SHOWN ARE FOR FINISHED PAVING, SIDEWALK, SLAB, OR GROUND. ADJUSTMENT TO SUBGRADE IS THE CONTRACTOR'S RESPONSIBILITY.
2. ALL DISTURBED AREAS THAT ARE SUBSURFACE OR ARE NOT DESIGNATED AS LANDSCAPE AREAS ARE TO BE SEEDED, FERTILIZED, AND WATERED UNTIL A HEALTHY STAND OF GRASS IS OBTAINED.
3. IF DURING THE OVERTOP GRADING PROCESS, CONDITIONS ARE ENCOUNTERED WHICH COULD INDICATE AN UNIDENTIFIED SITUATION IS PRESENT, THE SOILS ENGINEER SHALL BE CONTACTED FOR RECOMMENDATIONS.
4. UNLESS OTHERWISE SHOWN, NO PROPOSED SLOPE SHALL EXCEED THREE (3) HORIZONTAL TO ONE (1) VERTICAL. ALL SLOPED AREAS MUST BE PROTECTED FROM EROSION.
5. IF STRIPPED MATERIALS CONSISTING OF VEGETATION AND ORGANIC MATERIALS ARE STOCKPILED ON THE SITE, TOPSOIL MAY BE PLACED TO A HEIGHT OF FIVE FEET. SILT FENCE SHALL BE PLACED AROUND THE BASE OF THE STOCKPILE AND THE STOCKPILE SHALL BE SEEDED WITH NATIVE SEED MIX IMMEDIATELY AFTER STRIPPING OPERATIONS ARE COMPLETE.
6. SPOT ELEVATIONS SHALL TAKE PRECEDENCE OVER CONTOURS AND SLOPES SHOWN. THE CONTRACTOR SHALL NOTIFY THE ENGINEER OF SPOT ELEVATIONS THAT DO NOT APPEAR TO BE CONSISTENT WITH THE CONTOURS AND SLOPES. SPOT ELEVATIONS AND SPECIFIC PROFILE DESIGN SHALL BE USED FOR SETTING ELEVATIONS OF CURB, GUTTER, AND UTILITIES.
7. BENCHMARK VERIFICATION: CONTRACTOR SHALL USE BENCHMARKS AND DATUMS SHOWN HEREON TO SET PROJECT BENCH MARK'S, BY RUNNING A LEVEL LOOP BETWEEN AT LEAST TWO BENCHMARKS, AND SHALL PROVIDE SURVEY NOTES OF SUCH TO PROJECT ENGINEER PRIOR TO COMMENCING CONSTRUCTION.
8. ALL UTILITIES (MANHOLES, VALVE COVERS, CLEANOUTS, VAULTS, BOXES, ETC.) SHALL BE ADJUSTED TO FINAL GRADE PRIOR TO THE FINAL LIFT OF ASPHALT.
9. GRADES WITHIN ASPHALT PARKING AREAS SHALL BE CONSTRUCTED TO WITHIN 0.10 FEET OF THE DESIGN GRADE. HOWEVER, THE CONTRACTOR SHALL MAINTAIN POSITIVE DRAINAGE IN ALL PAVEMENT AREAS AND ALONG ALL CURBS. ALL CURBS SHALL BE BUILT IN ACCORDANCE TO THE PLAN. CURBS OR PAVEMENT AREAS WHICH DO NOT PROVIDE PROPER DRAINAGE MUST BE REMOVED AND REPLACED AT THE CONTRACTOR'S EXPENSE.
10. SPOT ELEVATIONS REPRESENT FLOW LINE OR TOP OF ASPHALT UNLESS OTHERWISE NOTED.
11. THE CONTRACTOR IS RESPONSIBLE FOR PROVIDING HIS OWN ESTIMATE OF EARTHWORK QUANTITIES.
12. WHERE NEW CURB AND GUTTER IS BEING CONSTRUCTED ADJACENT TO EXISTING ASPHALT OR CONCRETE PAVEMENT, THE FOLLOWING SHALL APPLY: PRIOR TO PLACEMENT OF ANY CONCRETE THE CONTRACTOR SHALL HAVE A LICENSED SURVEYOR VERIFY THE GRADE AND CROSS SLOPE OF THE CURB AND GUTTER FORMS. THE CONTRACTOR SHALL SUBMIT THE SLOPES AND GRADES TO THE ENGINEER FOR APPROVAL PRIOR TO PLACEMENT OF CONCRETE. THE CONTRACTOR SHALL NOTIFY THE ENGINEER IMMEDIATELY OF ANY SECTION WHICH DOES NOT CONFORM TO THE DESIGN OR TYPICAL CROSS SECTION. THE CONTRACTOR SHALL BE SOLELY RESPONSIBLE FOR CURB AND GUTTER POURS WITHOUT THE APPROVAL OF THE ENGINEER.
13. THE EARTHWORK FOR ALL BUILDING FOUNDATIONS AND SLABS SHALL BE IN ACCORDANCE WITH ARCHITECTURAL BUILDING PLANS AND SPECIFICATIONS.
14. PRE CAST STRUCTURES MAY BE USED AT CONTRACTORS OPTION.
15. EXISTING DRAINAGE STRUCTURES TO BE INSPECTED AND REPAIRED AS NEEDED, AND EXISTING PIPES TO BE CLEANED OUT TO REMOVE ALL SILT AND DEBRIS.
16. EXISTING GRADE CONTOUR INTERVALS SHOWN AT 1 FOOT INTERVALS.
17. IF ANY EXISTING STRUCTURES TO REMAIN ARE DAMAGED DURING CONSTRUCTION IT SHALL BE THE CONTRACTORS RESPONSIBILITY TO REPAIR AND/OR REPLACE THE EXISTING STRUCTURE AS NECESSARY TO RETURN IT TO EXISTING CONDITIONS OR BETTER.
18. CONTRACTOR SHALL ADJUST AND/OR CUT EXISTING PAVEMENT AS NECESSARY TO ASSURE A SMOOTH FIT AND CONTINUOUS GRADE.
19. CONTRACTOR SHALL ASSURE POSITIVE DRAINAGE AWAY FROM BUILDINGS FOR ALL NATURAL AND PAVED AREAS.
20. TOPOGRAPHIC INFORMATION TAKEN FROM A TOPOGRAPHIC SURVEY PROVIDED BY THE OWNER. IF CONTRACTOR DOES NOT ACCEPT EXISTING TOPOGRAPHY AS SHOWN ON THE PLANS, WITHOUT EXCEPTION, HE SHALL HAVE MADE, AT HIS EXPENSE, A TOPOGRAPHIC SURVEY BY A REGISTERED LAND SURVEYOR AND SUBMIT IT TO THE OWNER FOR REVIEW.
21. ALL SUBSURFACE AREA DISTURBED BY GRADING OPERATION SHALL RECEIVE 4 INCHES OF TOPSOIL. CONTRACTOR SHALL APPLY STABILIZATION FABRIC TO ALL SLOPES 3H:1V OR STEEPER. (CONTRACTOR SHALL PLACE SOD OR HYDROSEED DISTURBED AREAS IN ACCORDANCE WITH CITY/COUNTY SPECIFICATIONS AND MAINTAINED UNTIL A HEALTHY STAND OF GRASS IS OBTAINED.)
22. CONSTRUCTION SHALL COMPLY WITH ALL APPLICABLE GOVERNING CODES AND SITE SHALL BE CONSTRUCTED TO SAME.
23. CONTRACTOR IS RESPONSIBLE FOR VERIFYING ALL UTILITIES AND NOTIFYING THE APPROPRIATE UTILITY COMPANY PRIOR TO BEGINNING CONSTRUCTION.
24. THE CONTRACTOR IS SPECIFICALLY CAUTIONED THAT THE LOCATION AND/OR ELEVATION OF EXISTING UTILITIES AS SHOWN ON THESE PLANS IS BASED ON RECORDS OF THE VARIOUS UTILITY COMPANIES, AND WHERE POSSIBLE, MEASUREMENTS TAKEN IN THE FIELD. THE INFORMATION IS NOT TO BE RELIED ON AS BEING EXACT OR COMPLETE. THE CONTRACTOR MUST CALL THE APPROPRIATE UTILITY COMPANIES AT LEAST 72 HOURS BEFORE ANY EXCAVATION TO REQUEST EXACT FIELD LOCATIONS OF UTILITIES. IT SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR TO RELOCATE UTILITIES WHICH CONFLICT WITH THE PROPOSED IMPROVEMENTS SHOWN ON THE PLANS.
25. ENGINEER SHALL BE NOTIFIED WHEN 'CURBING STRING LINE' HAS BEEN SET, PRIOR TO CURBING BEING INSTALLED.
26. ALL DRYWELLS TO BE INSTALLED TO HAVE (1') ONE OF VERTICAL ADJUSTMENT.
27. ENGINEERING SHALL BE ON SITE, AND SHALL COLLECT TRUCK TICKETS FOR DRYWELL ROCK, AND SOIL.

STORM DRAINAGE NOTES

1. SEE STREET PLAN AND PROFILE SHEETS FOR DRYWELL AND CATCH BASIN TYPES AND LOCATIONS.
 2. SWALE/PONDS SHALL BE CONSTRUCTED PER THE REQUIREMENTS OF THESE DRAWINGS INCLUDING GRADING, SOD, AND DRYWELL INSTALLATION. ALL SWALES/PONDS WITH IN TRACTS SHALL INCLUDE AN IRRIGATION SYSTEM, ALL IRRIGATION SHALL CONFORM TO SPOKANE COUNTY SWALE/POND IRRIGATION SYSTEM GUIDELINES.
 3. ALL SWALES/PONDS SHOWN SHALL BE ROUGH GRADED PRIOR TO PAVING OF ADJACENT ROADWAY.
 4. CONTRACTOR SHALL PROVIDE SPOKANE COUNTY WITH AS-BUILT IRRIGATION PLANS UPON COMPLETION OF ALL SWALE/POND CONSTRUCTION.
 5. INSTALL "AMOCO" #4545 FILTER FABRIC (OR APPROVED EQUAL) BETWEEN THE NATIVE SOIL AND WASHED DRAIN ROCK, FOR ALL DRYWELLS. SEE SPOKANE COUNTY STANDARDS SHEET B-1a FOR INSTALLATION LOCATIONS.
 6. ALL SWALES/PONDS WITHIN THE RIGHT-OF-WAY, IN THE AREA ASSOCIATED WITH THIS PROJECT, SHALL BE COMPLETED DURING THE CONSTRUCTION OF THE ROADWAY. THE CONTRACTOR SHALL PERFORM THE SWALE/POND GRADE WORK, INSTALL THE IRRIGATION SYSTEM, AND PLACE THE SOD WITHIN THE SWALES/PONDS FOLLOWING THE ROAD PAVING WORK.
 7. THE CONTRACTOR SHALL MAKE AN EFFORT TO PROTECT ALL DRAINAGE STRUCTURES FROM BEING CONTAMINATED WITH SILT BY INSTALLING FILTER FABRIC UNDER THE LID FOR AT LEAST 6 WEEKS, OR UNTIL THE ESTABLISHMENT OF GRASS AND/OR OTHER SITE CONSTRUCTION WORK HAS ENDED. IN THE EVENT THAT SILT OR OTHER DELETERIOUS MATERIAL IS ALLOWED TO ENTER THE DRYWELL OR CATCH BASIN THE CONTRACTOR WILL BE REQUIRED TO CLEAN THE DRYWELL OR CATCH BASIN OUT TO THE SATISFACTION OF THE CERTIFYING ENGINEER.
 8. ALL LANDSCAPE AREAS (INCLUDING SWALES/PONDS) ARE TO BE IRRIGATED BY AN AUTOMATIC IRRIGATION SYSTEM SHALL BE INSTALLED BY OR UNDER THE DIRECTION OF THE LANDSCAPE CONTRACTOR. THE IRRIGATION SYSTEM SHALL COMPLY WITH ALL LOCAL CODES AND ORDINANCES (90 DAY GUARANTEE). AN APPROVED BACKFLOW DEVICE SHALL BE INSTALLED TO PREVENT WATER FOR GOING BACK INTO THE WATER SUPPLY.
 9. THE FLOOR OF ALL GRASSED PERCOLATION AREAS (GPA) (SWALES/PONDS) INCLUDES THE LEVEL PORTION OF THE FLOOR OF THE SWALES, AND THE SIDE SLOPES OF THE SWALE UP TO THE GPA OVERFLOW ELEVATION OR TOP OF DRYWELL. THE SOIL LOCATED IN THE FLOOR OF THE GPA SWALE SHALL BE A MEDIUM TO WELL-DRAINING MATERIAL, WITH A MINIMUM INFILTRATION RATE OF 0.5 INCHES PER HOUR. THE ENGINEER SHALL PROVIDE A WRITTEN STATEMENT WHICH VERIFIES THAT ALL GPA SWALES CONFORM TO THIS REQUIREMENT. THIS WRITTEN STATEMENT SHALL BE SUBMITTED TO THE SPOKANE COUNTY ENGINEER'S OFFICE PRIOR TO INSTALLING FINISHED LANDSCAPING/SOD AND PRIOR TO FINAL ACCEPTANCE. THE SWALE FLOOR MATERIAL SHALL BE INSTALLED TO A NATIVE SOIL STRATUM WHICH ALSO MEETS OR EXCEEDS THIS MINIMUM PERCOLATION RATE OF 0.5 INCHES PER HOUR, OR AS APPROVED BY SITE GEOTECHNICAL ENGINEER.
 10. WHEN TWO OR MORE CURB INLETS ARE USED, SET POND BOTTOM WITH RESPECT TO THE LOWEST CURB INLET GUTTER FLOWLINE ELEVATION.
 11. THE TOP 12" OF SOIL FOR ALL SWALE/POND BOTTOMS SHALL CONSIST OF THOROUGHLY BLENDED MIX OF 50% COMPOST WITH 50% NATIVE SOILS, OR AS APPROVED BY SITE GEOTECHNICAL ENGINEER.
 12. PER THE S.R.S.M. ALL SWALES/PONDS SHALL HAVE 12" OF TREATMENT SOIL WITH AN INFILTRATION RATE OF 0.5 INCHES/HOUR AND AVERAGE CATION EXCHANGE CAPACITY OF AT LEAST 15 MILLIGRAVIMENTS/100 GRAMS OR AT LEAST 2% OF ORGANIC MATTER BY WEIGHT. SEE TABLE 6-1, PG. 6-16 OF THE SPOKANE REGIONAL STORMWATER MANUAL, OR AS APPROVED BY SITE GEOTECHNICAL ENGINEER.
 13. WARNING: THE USE OF SILTY LOAM IS PROHIBITED AS SWALE/PONDS BOTTOM MATERIAL.
 14. ALL DRYWELLS TO HAVE 1' ONE VERTICAL FOOT OF ADJUSTMENT
 15. THE ENGINEER SHALL BE ON SITE, AND SHALL COLLECT TRUCK TICKETS FOR THE DRYWELL ROCK AND SOIL.
- SLEEVEING:** PROVIDE SLEEVEING AS REQUIRED UNDER SIDEWALKS, PATHS, CURBING, PAVING, ETC. AS NEEDED FOR IRRIGATION ACCESS. ALL SLEEVEING TO BE 4" PVC WITH AT LEAST 12" OF COVER (1) FOOT BELOW FINISH GRADE. THE OWNER/GENERAL CONTRACTOR IS RESPONSIBLE FOR INSTALLING SLEEVEING BEFORE CURBING, SIDEWALKS, PAVING, ETC. IS INSTALLED. PATCH ASPHALT AS NEEDED.
- LAWN AREAS:** LAWN AREAS ARE TO BE IRRIGATED WITH TORO POP-UP HEADS OR EQUIVALENT. (TEST SYSTEM BEFORE BACKFILLING).
- ADJUSTMENT:** AFTER INSTALLATION, ADJUST VALVES, HEADS, EMITTERS, ETC. TO PROVIDE UNIFORM COVERAGE AND TO MINIMIZE OVER SPRAY ON WALLS, FENCES, WALKS, DRIVES, ETC.
- WATER POWER SUPPLY:** THE OWNER/GENERAL CONTRACTOR IS TO SUPPLY WATER TAPS FOR HOOK-UP AND SUPPLY POWER FOR CONTROLLER.




SPOKANE COUNTY STREET NOTES

THE CONTRACTOR SHALL PROVIDE ALL MATERIALS, LABOR, AND EQUIPMENT TO CONSTRUCT AND INSTALL TO PROPER WORKING ORDER. ALL IMPROVEMENTS AS DETAILED OR CALLED OUT ON THESE PLANS.

1. ALL WORK AND MATERIALS SHALL BE IN CONFORMANCE WITH THE "SPOKANE COUNTY STANDARDS FOR ROAD AND SEWER CONSTRUCTION, CURRENT EDITION", AND AS AMENDED.
2. THE CONTRACTOR IS REQUIRED TO HAVE A VALID CONSTRUCTION PERMIT ON SITE AT ALL TIMES. THE ABSENCE OF THE PERMIT WILL RESULT IN AN IMMEDIATE SHUTDOWN OF WORK AND THE POSSIBLE REMOVAL OF THOSE ITEMS CONSTRUCTED WITHOUT THE PERMIT.
3. LOCATIONS OF EXISTING UTILITIES SHOWN IN THE PLANS ARE APPROXIMATE. THE CONTRACTOR SHALL BE RESPONSIBLE FOR LOCATING ALL UNDERGROUND UTILITIES. ANY CONFLICTING UTILITIES SHALL BE RELOCATED PRIOR TO CONSTRUCTION OF ROAD AND DRAINAGE FACILITIES.
4. THE CONTRACTOR IS REQUIRED TO HAVE A COMPLETE SET OF THE APPROVED ROAD AND DRAINAGE PLANS ON THE JOB SITE WHENEVER CONSTRUCTION IS IN PROGRESS.
5. IF THE CONTRACTOR DISCOVERS ANY DISCREPANCIES BETWEEN THE PLANS AND EXISTING CONDITIONS ENCOUNTERED, THE CONTRACTOR SHALL IMMEDIATELY NOTIFY THE DESIGN ENGINEER, TODD R WHIPPLE, P.E., @ 893-2617, THE SITE/PROJECT INSPECTING ENGINEER OR HIS REPRESENTATIVE, IPEC, PAUL T. NELSON, P.E., @ 509-290-5179 AND THE SPOKANE COUNTY ENGINEER'S OFFICE, CONSTRUCTION ENGINEER, @ 477-3600.
6. FOR CONSTRUCTION OF DRYWELLS, INSTALL FILTER FABRIC, "AMOCO" 4545 OR APPROVED EQUAL, BETWEEN THE DRYWELL BARREL AND THE WASHED DRAINROCK AND BETWEEN THE WASHED DRAINROCK AND NATIVE SOILS PER SPOKANE COUNTY STANDARD DETAIL B-1a.
7. PRIOR TO SITE CONSTRUCTION, THE CONTRACTOR IS RESPONSIBLE FOR LOCATING ALL UNDERGROUND UTILITIES. CALL THE UNDERGROUND UTILITY LOCATION SERVICE AT 456-8000 BEFORE YOU DIG.
8. THE CONTRACTOR SHALL MAKE AN EFFORT TO PROTECT ALL CATCH BASINS AND DRYWELLS FROM BEING CONTAMINATED WITH SILT BY INSTALLING FILTER FABRIC UNDER THE LID FOR AT LEAST 6 WEEKS, OR UNTIL THE ESTABLISHMENT OF GRASS AND/OR OTHER SITE CONSTRUCTION WORK HAS ENDED.
9. IN THE EVENT THAT SILT OR OTHER DELETERIOUS MATERIAL IS ALLOWED TO ENTER THE DRYWELLS OR CATCH BASINS THE CONTRACTOR WILL BE REQUIRED TO CLEAN OUT THE DRYWELL OR CATCH BASIN TO THE SATISFACTION OF THE CERTIFYING ENGINEER.
10. THE CONTRACTOR SHALL EMPLOY A LICENSED SURVEYOR TO VERIFY THAT THE CROSS- GUTTER FORMS ARE THE CORRECT PLANE GRADE PRIOR TO CONCRETE PLACEMENT. THE CROSS-GUTTERS SHALL BE CONSTRUCTED PRIOR TO PAVING, AND THE PAVEMENT SHALL THEN MATCH THE EDGE OF CONCRETE GUTTER.
11. ALL DRYWELL CONNECTION PIPES SHALL BE PLACED BELOW THE DRYWELL CONE AND SHALL FLOW AS DIRECTED IN THE PLANS.
12. FOR ANY CURB GRADES LESS THAN 0.8 % (0.008 FT./FT.), A WASHINGTON STATE LICENSED PROFESSIONAL LAND SURVEYOR SHALL VERIFY THAT THE CURB FORMS ARE AT THE GRADES NOTED ON THE APPROVED PLANS, PRIOR TO PLACEMENT OF CURB MATERIAL. THE CONTRACTOR IS RESPONSIBLE FOR ARRANGING AND COORDINATING WORK WITH THE PROFESSIONAL LAND SURVEYOR.

PLANS
 NOT APPROVED
 BY AGENCY



10/13/16
**SHEET
 CO.1**
 JOB NUMBER
13-1166

NAVD - 88
 TBM S-6 OF THE SOUTH PONDEROSA SEWER PROJECT
 WITH AN ELEVATION OF 2005.87 (NAVD29)=2009.67
 (NAVD88) WAS USED FOR THE VERTICAL DATUM FOR THIS
 MAP.

A	08/03/16	RMA	ORIGINAL PREPARATION		
			REVISIONS		
	NO.	DATE	BY		

SCALE:	
HORIZONTAL:	N/A
VERTICAL:	N/A


PROJ #:	13-1166
DATE:	08/03/16
DRAWN:	RMA
REVIEWED:	TRW

<input checked="" type="checkbox"/>	CIVIL
<input type="checkbox"/>	STRUCTURAL
<input type="checkbox"/>	SURVEYING
<input type="checkbox"/>	TRAFFIC
<input type="checkbox"/>	PLANNING
<input type="checkbox"/>	LANDSCAPE
<input type="checkbox"/>	OTHER



**GUSTIN DITCH IMPROVEMENT PLANS
 GENERAL NOTES
 40TH AVENUE
 SPOKANE COUNTY, WA**

SE 1/4, SEC. 33, T. 25N., R. 44E., W.M.
 SW 1/4, SEC. 34, T. 25N., R. 44E., W.M.
 NE 1/4, SEC. 4, T. 24N., R. 44E., W.M.



LEGEND

- BT----- BURIED TELEPHONE
- OP----- OVERHEAD POWER
- WP----- EXISTING WATER PIPE
- SP----- EXISTING SEWER PIPE
- GL----- EXISTING GAS LINE
- SL----- EXISTING SIDEWALK
- PL----- PAVEMENT LINE
- CL----- EXISTING CURB
- PL----- PROPERTY LINE
- FX----- EXISTING FENCE
- TELEPHONE MANHOLE
- WATER MANHOLE
- ⊙ SEWER MANHOLE
- ▲ SIGN
- LIGHT POLE
- TREE (DECIDUOUS)
- ★ TREE (CONIFER)
- BOLLARD
- ⊗ WATER VALVE
- ⊕ FIRE HYDRANT
- ⊞ WATER METER
- ⊟ GUY ANCHOR
- IRRIGATION BOX
- ⊖ POWER POLE

TOPOGRAPHIC SURVEY

SCALE: 1" = 60'

SURVEYORS' NOTE:

1. UTILITIES SHOWN HEREON ARE FROM VISIBLE SURFACE EVIDENCE COLLECTED BY SURVEY. INVESTIGATION INTO RECORDS HELD BY UTILITY PURVEYORS HAS NOT BEEN PERFORMED. LOCATES FOR UNDERGROUND UTILITIES WERE ORDERED AND ARE SHOWN ON THIS MAP.
 2. SOME ITEMS MIGHT BE MISSING ON THIS MAP AND NOT LOCATED DUE TO THE FACT THAT IT WAS AN ACTIVE PARKING LOT.

THIS MAP CORRECTLY REPRESENTS A TOPOGRAPHIC SURVEY PERFORMED BY ME, OR UNDER MY DIRECTION, IN AUGUST OF 2014 AT THE REQUEST OF BRIAN WALKER.
 JON A. GORDON, P.L.S.
 CERTIFICATE NO. 43610

08/03/16

ABBREVIATIONS

ACT. LEN. ACTUAL LENGTH	GB GRADE BREAK	PRC POINT OF REVERSE CURVE
BCR BEGINNING OF CURVE RADIUS	FT./FT. FEET PER FOOT	PT POINT OF TANGENCY
BDRY. BOUNDARY	HYD. HYDRANT	RIM EL. RIM ELEVATION
CO. SEWER CLEANOUT	I.E. INVERT ELEVATION	RD ROAD
CSTC CRUSHED SURFACE	LN. LANE	RT. RIGHT
TOP COURSE	LT. LEFT	SI STREET INTERSECTION
CT COURT	MH MANHOLE	SS SANITARY SEWER
DIA. DIAMETER	MCR MIDDLE OF CURVE RADIUS	STA. STATION
ECR END OF CURVE RADIUS	PC POINT OF CURVATURE	STA. LEN. STATION LENGTH
EXIST. EXISTING	PET. PETROLEUM	TG TOP OF GRATE
G GRADE	PI POINT OF INTERSECTION	TC TOP OF CURB

NAVD - 88


TBM S-5 OF THE SOUTH PONDEROSA SEWER PROJECT WITH AN ELEVATION OF 2005.87 (NAVD29) - 2009.67 (NAVD88) WAS USED FOR THE VERTICAL DATUM FOR THIS MAP.

SCALE:	
HORIZONTAL:	1" = 60'
VERTICAL:	N/A

NO.	DATE	BY	REVISIONS
A	08/03/16	RMA	ORIGINAL PREPARATION

PROJ #: 13-1166
 DATE: 08/03/16
 DRAWN: RMA
 REVIEWED: TRW

<input checked="" type="checkbox"/> CIVIL
<input type="checkbox"/> STRUCTURAL
<input type="checkbox"/> SURVEYING
<input type="checkbox"/> TRAFFIC
<input type="checkbox"/> PLANNING
<input type="checkbox"/> LANDSCAPE
<input type="checkbox"/> OTHER



GUSTIN DITCH IMPROVEMENT PLANS
TOPOGRAPHIC SURVEY (REF. ONLY)
40TH AVENUE
SPOKANE COUNTY, WA


PLANS NOT APPROVED BY AGENCY

Spokane County Permit No.:

Floodplain-Grading-

City of Spokane Valley Permit No.:

SUB-2015-0001
 FPD-2016-
 EGR-201X-XXXX





SHEET C1.0



JOB NUMBER
13-1166

SE 1/4, SEC. 33, T. 25N., R. 44E., W.M.
 SW 1/4, SEC. 34, T. 25N., R. 44E., W.M.
 NE 1/4, SEC. 4, T. 24N., R. 44E., W.M.

UNDERGROUND SERVICE ALERT
 ONE-CALL NUMBER
811
 CALL TWO BUSINESS DAYS BEFORE YOU DIG




NOTE:
 1. FG = TOP OF LEVEE
 REQUIRED FREEBOARD = BFE+3'
 RAS STATION = RIVER ANALYSIS SYSTEM STATION
 2. NORTHING AND EASTING IS BASED ON THE
 NORTHEAST PROPERTY CORNER. SEE SHEET C5.0
 FOR CORNER LOCATION. COORDINATES 0,0.



CONSTRUCTION NOTES

- ① CONSTRUCT DRAINAGE POND, SEE SHEET C5.0 FOR DETAILS.
- ② PROVIDE AND INSTALL LEVEE AT SPECIFIED ELEVATION PER DETAIL 1, THIS SHEET.
- ③ REMOVE EXISTING CROSSING.
- ④ PROVIDE AND INSTALL 8' WIDE 6" CSTC ACCESS TURNAROUND ON TOP OF LEVEE.
- ⑤ PROVIDE AND INSTALL 36" CMP PIPE PER SPOKANE STANDARDS AND SPECIFICATIONS. SEE PLAN FOR DETAILS.

- LEVEE CONSTRUCTION NOTES:**
1. REMOVE EXISTING TOP SOIL, ORGANICS, AND FILL FROM DITCH AND LEVEE FOOTPRINT. SCARIFY AND RECOMPACT A MINIMUM OF ONE FOOT BELOW LEVEE AND DITCH.
 2. CONSTRUCT LEVEE WITH GRANULAR SOIL WITH 10-30% PASSING 200 SIEVE, COMPACTED TO 92% PER ASTM D 1557. SEE GEOTECH REPORT TITLED GUSTIN LEVEE EVALUATION PROJECT NO.14-037B BY IPEC ON DATED JULY 23, 2015.
 3. REVEGETATE LEVEE AND DITCH WITH DRYLAND GRASS AND IRRIGATE UNTIL ESTABLISHED. SEE SEED MIX DETAIL A ON SHEET C5.0.
 4. SEE OPERATING & MAINTENANCE MANUAL FOR CARE.



**FOR FULL LEGEND
 SEE SHEET C0.0**

NAVD - 88
 TBM S-5 OF THE SOUTH PONDEROSA SEWER PROJECT
 WITH AN ELEVATION OF 2005.87 (NAVD29) - 2009.67
 (NAVD88) WAS USED FOR THE VERTICAL DATUM FOR THIS
 MAP.

NO.	DATE	BY	REVISIONS
A	08/03/16	RMA	ORIGINAL PREPARATION

SCALE:	PROJ #: 13-1166	DATE: 08/03/16
HORIZONTAL: 1" = 30'	DRAWN: RMA	REVIEWED: TRW
VERTICAL: N/A		

WCE
 WHIPPLE CONSULTING ENGINEERS
 2528 NORTH SULLIVAN ROAD
 SPOKANE VALLEY, WA 99216
 PH: 509-893-2617 FAX: 509-826-0227

**GUSTIN DITCH IMPROVEMENT PLANS
 LEVEE GRADING PLAN
 40TH AVENUE
 SPOKANE COUNTY, WA**

Spokane County Permit No.:
 Floodplain-Grading-
 City of Spokane Valley Permit No.:
 SUB-2015-0001
 FPD-2016-
 EGR-201X-XXXX





SHEET C4.0
 JOB NUMBER 13-1166

PLANS NOT APPROVED BY AGENCY

P:\WCE_WORK\2013 WCE PROJECTS\2013-1166 Walker - Painted Hills.GCDWG\GUSTIN-C4.0 GRADING.dwg, 10/13/2016 1:43:46 PM

SE 1/4, SEC. 33, T. 25N., R. 44E., W.M.
 SW 1/4, SEC. 34, T. 25N., R. 44E., W.M.
 NE 1/4, SEC. 4, T. 24N., R. 44E., W.M.

UNDERGROUND SERVICE ALERT
 ONE-CALL NUMBER
811
 CALL TWO BUSINESS DAYS BEFORE YOU DIG



- CONSTRUCTION NOTES**
- 1 CONSTRUCT DETENTION POND PER DETAILS, THIS SHEET.
 - 2 PROVIDE AND INSTALL TYPE B DRYWELL PER CITY OF SPOKANE VALLEY STANDARD PLAN S-101. SET RIM ELEVATION 2 FEET ABOVE POND BOTTOM ELEVATION.
 - 3 MATCH ACCESS ROAD TO EXISTING EDGE OF ASPHALT.
 - 4 RESERVED
 - 5 PROVIDE AND INSTALL 15' WIDE MAINTENANCE ACCESS ROAD. 6" CSTC ON 95% COMPACTED SUBGRADE.
 - 6 PROVIDE AND INSTALL 6"-12", D₅₀ 12" DIAMETER ROCK ARMOR IN 12' WIDE V-DITCH WITH 6:1 SLOPE. SEE DETAIL C, THIS SHEET.
 - 7 PROVIDE AND INSTALL 12"-24", D₅₀ 18" ROCK RIP-RAP WITH A 6' X 12' PAD 2 FT THICK. PLACE GEOTEXTILE UNDER ROCK.
 - 8 SEED DRYLAND GRASS MIX. SEE NOTE A BELOW. IRRIGATE UNTIL ESTABLISHED.
 - 9 SEED SWORD HARD FESCUE GRASS MIX. SEE NOTE B BELOW. IRRIGATE UNTIL ESTABLISHED.
 - 10 INSTALL 12' DOUBLE SWING CHAINLINK GATE IN EXISTING FENCE.
 - 11 PROVIDE AND INSTALL 12' WIDE MAINTENANCE ACCESS ROAD. 6" CSTC ON COMPACTED SUBGRADE.

SEEDING NOTE: (A)
 GRASS SEED: PROVIDE FRESH, CLEAN, NEW-CROP SEED COMPLYING WITH TOLERANCE OF PURITY AND GERMINATION ESTABLISHED BY THE OFFICIAL SEED ANALYSIS OF NORTH AMERICAN. PROVIDE SEED MIXTURE COMPOSED OF GRASS SPECIES AND PERCENTAGES AS FOLLOWS:

10 PER CENT	ELKA PERENNIAL RYE
20 PER CENT	DURAR HARD FESCUE
45 PER CENT	COVAR SHEEP/FESCUE
15 PER CENT	REUBENS CANADIAN BLUEGRASS

PROVIDE MIXTURE COMPOSED OF GRASS SEED AND FERTILIZER IN PERCENTAGES AS FOLLOWS:

GRASS SEED: 90 LBS. PER ACRE
 FERTILIZER: 16-16-16 TIMED RELEASE COMPOSITION, 300 LBS. PER ACRE

ALL SEEDING OF SLOPES SHALL BE DONE IN ACCORDANCE WITH THE W.S.D.O.T. STANDARD SPECIFICATIONS, SECTION 8-01.


SEEDING NOTE: (B)
 GRASS SEED: PROVIDE FRESH, CLEAN, NEW-CROP SEED COMPLYING WITH TOLERANCE OF PURITY AND GERMINATION ESTABLISHED BY THE OFFICIAL SEED ANALYSIS OF NORTH AMERICAN. PROVIDE SEED MIXTURE COMPOSED OF GRASS SPECIES AND PERCENTAGES AS FOLLOWS:

GRASS SEED MIX: SWORD HARD FESCUE (FESTUCA LONGIFOLIA)

NEW SEEDING RATE: 2-4 LBS/1,000 SQ FT

PROVIDER: LANDMARK TURF & NATIVE SEED
 PH: (509) 835-4967

POND
 FINISHED GRADE POND BOTTOM EL=1990.00
 POND BOTTOM AREA PROVIDED=17060 S.F.



NAVD - 88
 TBM S-5 OF THE SOUTH PONDEROSA SEWER PROJECT WITH AN ELEVATION OF 2005.87 (NAVD29) - 2009.67 (NAVD88) WAS USED FOR THE VERTICAL DATUM FOR THIS MAP.

NO.	DATE	BY	REVISIONS
A	08/03/16	RMA	ORIGINAL PREPARATION

SCALE:	PROJ #: 13-1166	DATE: 08/03/16
HORIZONTAL:	DRAWN: RMA	REVIEWED: TRW
VERTICAL:	N/A	

WCE
 WHIPPLE CONSULTING ENGINEERS
 2528 NORTH SULLIVAN ROAD
 SPOKANE VALLEY, WA 99216
 PH: 509-893-2617, FAX: 509-826-0227


GUSTIN DITCH IMPROVEMENT PLANS
TRIANGLE POND DETAIL
40TH AVENUE
SPOKANE COUNTY, WA

Spokane County Permit No.:
 Floodplain-Grading-
 City of Spokane Valley Permit No.:
 SUB-2015-0001
 FPD-2016-
 EGR-201X-XXXX

PLANS NOT APPROVED BY AGENCY

SHEET C5.0

JOB NUMBER
13-1166



P:\WCE_WORK\2013 WCE PROJECTS\2013-1166 Walker - Painted Hills\GUSTIN-C5.0_POND.dwg, 10/13/2016 1:44:38 PM

GENERAL NOTES

1. ALL MATERIALS, WORKMANSHIP, AND CONSTRUCTION OF SITE IMPROVEMENTS SHALL MEET OR EXCEED SITE WORK STANDARDS AND THE STANDARDS AND SPECIFICATIONS SET FORTH IN SPOKANE COUNTY REGULATIONS AND APPLICABLE STATE AND FEDERAL REGULATIONS. WHERE THERE IS CONFLICT BETWEEN THESE PLANS AND THE SPECIFICATIONS, OR ANY APPLICABLE STANDARDS, THE HIGHER QUALITY STANDARD SHALL APPLY. ALL WORK WITHIN PUBLIC R.O.W. OR EASEMENTS SHALL BE INSPECTED AND APPROVED BY SPOKANE COUNTY INSPECTOR. INSPECTION SERVICES AND CONSTRUCTION CERTIFICATION TO BE PROVIDED BY DESIGNEE OF PROJECT SPONSOR/OWNER.
2. THE CONTRACTOR IS SPECIFICALLY CAUTIONED THAT THE LOCATION AND/OR ELEVATION OF EXISTING UTILITIES, AS SHOWN ON THESE PLANS, IS BASED ON RECORDS OF THE VARIOUS UTILITY COMPANIES AND, WHERE POSSIBLE, MEASUREMENTS TAKEN IN THE FIELD. THE INFORMATION IS NOT TO BE RELIED UPON AS BEING EXACT OR COMPLETE. THE CONTRACTOR MUST CALL THE LOCAL UTILITY LOCATION CENTER AT LEAST 48 HOURS BEFORE ANY EXCAVATION TO REQUEST EXACT FIELD LOCATIONS OF EXISTING UTILITIES. THE CONTRACTOR SHALL VERIFY PERTINENT LOCATIONS AND ELEVATIONS, ESPECIALLY AT THE CONNECTION POINTS AND AT POTENTIAL UTILITY CONFLICTS. IT SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR TO RELOCATE ALL EXISTING UTILITIES THAT CONFLICT WITH THE PROPOSED IMPROVEMENTS SHOWN ON THESE PLANS.
3. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS FROM ALL APPLICABLE AGENCIES. THE CONTRACTOR SHALL NOTIFY SPOKANE COUNTY INSPECTOR AT LEAST 48 HOURS PRIOR TO THE START OF ANY EARTH DISTURBING ACTIVITY OR CONSTRUCTION ON ANY AND ALL PUBLIC IMPROVEMENTS.
4. THE CONTRACTOR SHALL COORDINATE AND COOPERATE WITH SPOKANE COUNTY AND ALL UTILITY COMPANIES WITH REGARD TO RELOCATIONS OR ADJUSTMENTS OF EXISTING UTILITIES DURING CONSTRUCTION, TO ASSURE THAT THE WORK IS ACCOMPLISHED IN A TIMELY FASHION, AND WITH A MINIMUM DISRUPTION OF SERVICE. THE CONTRACTOR SHALL BE RESPONSIBLE FOR CONTACTING ALL PARTIES AFFECTED BY ANY DISRUPTION OF ANY UTILITY SERVICE.
5. THE CONTRACTOR SHALL HAVE ONE (1) SIGNED COPY OF THE APPROVED PLANS, ONE (1) COPY OF THE APPROPRIATE STANDARDS AND SPECIFICATIONS, AND ONE (1) COPY OF ANY PERMITS AND EXTENSION AGREEMENTS NEEDED FOR THE JOB ON-SITE AT ALL TIMES.
6. THE CONTRACTOR SHALL BE RESPONSIBLE FOR ALL ASPECTS OF SAFETY INCLUDING, BUT NOT LIMITED TO: EXCAVATION, TRENCHING, SHORING, TRAFFIC CONTROL, AND SECURITY.
7. IF, DURING THE CONSTRUCTION PROCESS, CONDITIONS ARE ENCOUNTERED BY THE CONTRACTOR, HIS SUBCONTRACTORS, OR OTHER AFFECTED PARTIES WHICH COULD INDICATE A SITUATION THAT IS NOT IDENTIFIED IN THE PLANS OR SPECIFICATIONS, THE CONTRACTOR SHALL CONTACT THE ENGINEER IMMEDIATELY.
8. ALL REFERENCES TO ANY PUBLISHED STANDARDS SHALL REFER TO THE LATEST REVISION OF SAID STANDARD, UNLESS SPECIFICALLY STATED OTHERWISE.
9. FOR WORK AFFECTING PUBLIC ROADWAYS OR IF REQUIRED BY SPOKANE COUNTY, THE CONTRACTOR SHALL SUBMIT A TRAFFIC CONTROL AND PHASING PLAN IN ACCORDANCE WITH M.U.T.C.D. FOR APPROVAL PRIOR TO ANY CONSTRUCTION ACTIVITIES WITHIN OR AFFECTING THE RIGHT-OF-WAY, THE CONTRACTOR SHALL BE RESPONSIBLE FOR PROVIDING ANY AND ALL TRAFFIC CONTROL DEVICES AS MAY BE REQUIRED BY SAID PLANS. PRIOR TO INSTALLATION, A RECONSTRUCTION CONFERENCE SHALL BE HELD WITH SPOKANE COUNTY.
10. THE CONTRACTOR IS RESPONSIBLE FOR PROVIDING ALL LABOR AND MATERIALS NECESSARY FOR THE COMPLETION OF THE INTENDED IMPROVEMENTS SHOWN ON THESE DRAWINGS OR DESIGNATED TO BE PROVIDED, INSTALLED, CONSTRUCTED, REMOVED OR RELOCATED UNLESS SPECIFICALLY NOTED OTHERWISE.
11. PER AGENCY STANDARDS THE CONTRACTOR SHALL BE RESPONSIBLE FOR KEEPING ROADWAYS FREE AND CLEAR OF ALL CONSTRUCTION DEBRIS AND DIRT TRACKED FROM THE SITE.
12. THE CONTRACTOR SHALL BE RESPONSIBLE FOR RECORDING RECORD INFORMATION ON A SET OF RECORD DRAWINGS KEPT AT THE CONSTRUCTION SITE AND AVAILABLE TO SPOKANE COUNTY INSPECTOR AT ALL TIMES.
13. DIMENSIONS FOR LAYOUT AND CONSTRUCTION ARE NOT TO BE SCALED FROM ANY DRAWING. FOR ADDITIONAL INFORMATION CONTACT THE ENGINEER FOR CLARIFICATION AND NOTE ON THE RECORD DRAWINGS.
14. ALL EROSION AND SEDIMENT CONTROL (E.S.C.) MEASURES SHALL BE INSTALLED AT THE LIMITS OF CONSTRUCTION PRIOR TO GROUND DISTURBING ACTIVITY. ALL E.S.C. MEASURES SHALL BE MAINTAINED IN GOOD REPAIR BY THE CONTRACTOR UNTIL SUCH TIME AS THE ENTIRE DISTURBED AREAS ARE STABILIZED WITH HARD SURFACE OR LANDSCAPING.
15. THE CONTRACTOR SHALL SEQUENCE INSTALLATION OF UTILITIES IN SUCH A MANNER AS TO MINIMIZE POTENTIAL UTILITY CONFLICTS. IN GENERAL, STORM SEWER AND SANITARY SEWER SHOULD BE CONSTRUCTED PRIOR TO INSTALLATION OF WATER LINES AND DRY UTILITIES. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO COORDINATE ALL UTILITY RELOCATIONS CONSISTENT WITH THE CONTRACTORS SCHEDULE FOR THIS PROJECT, WHETHER SHOWN OR NOT SHOWN, AS IT RELATES TO THE CONSTRUCTION ACTIVITIES CONTEMPLATED IN THESE PLANS.
16. ALL WORK WITHIN THE PUBLIC RIGHT-OF-WAY IS SUBJECT TO THE JURISDICTION OF SPOKANE COUNTY ENGINEERING DEPARTMENT STANDARD DETAILS AND SPECIFICATIONS.
17. ALL CONSTRUCTION OPERATIONS, INCLUDING THE WARMING UP, REPAIR, ARRIVAL, DEPARTURE OR RUNNING OF TRUCKS, EARTH MOVING EQUIPMENT, CONSTRUCTION EQUIPMENT AND ANY OTHER ASSOCIATED EQUIPMENT SHALL GENERALLY BE LIMITED TO THE TIME PERIOD APPROVED BY SPOKANE COUNTY.
18. BASED ON REQUIREMENTS FROM SPOKANE COUNTY, THE ENGINEER OR HIS DESIGNEE SHALL PERFORM MATERIALS TESTING AND QUALITY CONTROL ON THE PROJECT AND SHALL SUBMIT COPIES OF DAILY REPORTS, TEST REPORTS, PROJECT CERTIFICATION AND RECORD DRAWINGS TO THE CITY OF SPOKANE VALLEY/SPOKANE COUNTY ENGINEER.
19. NO REVISIONS SHALL BE MADE TO THESE PLANS WITHOUT APPROVAL OF SPOKANE COUNTY ENGINEERS AND NOTIFICATION OF THE ENGINEER OF RECORD.
20. ON-SITE GRADING SHALL BE IN ACCORDANCE WITH THE APPROVED GRADING PLAN AND E.S.C. PLAN. ANY IMPORT OR EXPORT OF MATERIAL SHALL BE FROM AN REPROVED SOURCE/DESTINATION AND COORDINATED WITH SPOKANE COUNTY DEPARTMENT OF BUILDING AND PLANNING 509-477-3675. GRADING ON THIS SITE OR ANY OTHER SITE MUST COMPLY WITH ALL DEVELOPMENT REGULATIONS INCLUDING, BUT NOT LIMITED TO, GRADING PERMITS, S.E.P.A. REVIEW, TIMBER HARVEST PERMITS, CRITICAL AREAS, FLOOD PLAINS, DESIGNATED DRAINAGE WAYS, ETC.
21. THE CONTRACTOR IS CAUTIONED THAT IT IS THE UNDERSTANDING OF THE OWNER AND THE ENGINEER THAT SHOULD A CONFLICT OR DISCREPANCY IN THESE PLANS, SPECIFICATIONS, GENERAL NOTES OR PLANS ET.AL. DETERMINED TO BE PART OF THE OVERALL PROJECT, INCLUDING BUT NOT LIMITED TO THE ARCHITECTURAL PLANS, MECHANICAL PLANS, ELECTRICAL PLANS, LANDSCAPE PLANS, GENERAL SPECIAL PROVISIONS, ETC., THAT WITHOUT WRITTEN CLARIFICATION FROM THE ENGINEER, OWNER OR OTHER PROFESSIONAL, DURING THE BIDDING PROCESS, THAT IN ALL INSTANCES THE CONTRACTOR WILL BE REQUIRED TO BID THE HIGHER STANDARD. FAILURE TO DO SO MAY RESULT IN THE HIGHER STANDARD BEING REQUIRED BY THE OWNER, ENGINEER OR OTHER PROFESSIONAL WITH NO CHANGE IN VALUE TO THE CONTRACT VIA CHANGE ORDER OR OTHER MECHANISM.
22. CONSTRUCTION OF EVERY DRYWELL, INCLUDING FABRIC AND DRAINROCK, SHALL BE OBSERVED BY THE ON-SITE INSPECTOR TO CONFIRM THAT IT MEETS THE DESIGN DETAILS AND SPECIFICATIONS. DRYWELLS NOT OBSERVED SHALL HAVE THEIR PERFORMANCE VERIFIED BY A FULL-SCALE DRYWELL TEST.

NAVD - 88
TBM S-5 OF THE SOUTH PONDEROSA SEWER PROJECT WITH AN ELEVATION OF 2005.87 (NAVD209) = 2009.67 (NAVD88) WAS USED FOR THE VERTICAL DATUM FOR THIS MAP.

SE 1/4, SEC. 33, T. 25 N., R. 44 E., W.M.
SW 1/4, SEC. 34, T. 25 N., R. 44 E., W.M.
NE 1/4, SEC. 4, T. 24 N., R. 44 E., W.M.

SWPPP/EROSION CONTROL PLAN


PAINTED HILLS - GUSTIN DITCH

40TH AVENUE

SPOKANE COUNTY, WASHINGTON

SE 1/4 OF SEC. 33, T. 25 N., R. 44 E., W.M.


UNDERGROUND SERVICE ALERT
ONE-CALL NUMBER
811
CALL TWO BUSINESS DAYS BEFORE YOU DIG



LOCATION MAP

INDEX TO PLAN SHEETS

- C9.0 SWPPP/EROSION CONTROL COVER SHEET
- C9.1 SWPPP NOTES
- C9.2 SWPPP BMP'S
- C9.3 SWPPP BMP'S




SITE PLAN

SCALE: 1" = 100'

LEGEND

- STORM DRAINAGE POND - NO CONCRETE TRUCK WASHOUT AREA.
- BMP C233: SILT FENCE, SHEET C9.2.
- BMP C105: STABILIZED CONSTRUCTION ENTRY, SHEET C9.2
- BMP C220: STORM DRAIN INLET PROTECTION, SHEET C9.3.
- BMP C151: CONCRETE HANDLING - MAY ONLY TAKE PLACE ON UNCOMPACTED SUBGRADE AFTER ASPHALT REMOVAL, AND IN A NON-LANDSCAPED AREA. OTHERWISE ANY CONCRETE WASHOUT MUST BE OFF SITE. SHEET C9.3.
- LIMITS OF DISTURBANCE



PLANS NOT APPROVED BY AGENCY

Spokane County Permit No.:

Floodplain-Grading-

City of Spokane Valley Permit No.:

SUB-2015-0001
FPD-2016
EGR-201X-XXXX

W. WHIPPLE
REGISTERED PROFESSIONAL ENGINEER
10/13/16

PERMIT SPECIALIST
CITY OF SPOKANE VALLEY
PERMIT CENTER
11707 E SPRAGUE AVE
SPOKANE, WA 99206
PHONE: 720-5240

DEV. CONST. INSP.
CITY OF SPOKANE VALLEY
11707 E SPRAGUE AVE
SPOKANE, WA 99206
PHONE: 720-5324
CONTACT: JOHN JOHNSON

SOLID WASTE
WASTE MANAGEMENT
PHONE: 1-866-909-4458

SEWER
SPOKANE COUNTY UTILITIES
1225 N YARDELEY ST
SPOKANE, WA 99206
PHONE: 477-7180
CONTACT: CHRIS KNUDSON

HEALTH
SPOKANE REGIONAL HEALTH
1101 W COLLEGE AVE
SPOKANE, WA 99260
PHONE: 324-1578
CONTACT: PAUL SAVAGE

INSPECTION
I.P.E.C.
P. O. BOX 1566
VERADALE, WA 99037
PHONE: 209-6262
CONTACT: PAUL T. NELSON, P.E.

WATER
SPOKANE COUNTY WATER DISTRICT #3
11026 W BROADWAY AVE
SPOKANE, WA 99206
PHONE: 536-0121
CONTACT: TY WICK

GAS
AVISTA UTILITIES
1101 W COLLEGE AVE
SPOKANE, WA 99220
PHONE: 495-8610
CONTACT: KEN CARLSON

SURVEYOR
WHIPPLE CONSULTING ENGINEERS
2528 N SULLIVAN RD
SPOKANE VALLEY, WA 99216
PHONE: 893-2617
CONTACT: JON GORDON, P.L.S.

FIRE
SPOKANE VALLEY FIRE DEPT.
2120 N WILBUR RD
SPOKANE VALLEY, WA 99206
PHONE: 923-1700
CONTACT: TRACI HARVEY

TELEPHONE
CENTURY LINK
904 N COLUMBUS ST
SPOKANE, WA 99202
PHONE: 623-0305
CONTACT: DEBORAH GEIST

ENGINEERING
WHIPPLE CONSULTING ENGINEERS
2528 N SULLIVAN RD
SPOKANE VALLEY, WA 99216
PHONE: 893-2617
CONTACT: TODD WHIPPLE, P.E.

POWER
INLAND POWER & LIGHT OPERATIONS DEPARTMENT
P.O. BOX A
SPOKANE, WASHINGTON 99219
PHONE: 789-4291
CONTACT: CONNIE NELSON

CABLE
COMCAST BROADBAND
1717 E BUCKEYE AVE
SPOKANE, WA 99207
PHONE: 755-4717
CONTACT: BRYAN RICHARDSON

OWNER
BRYAN WALKER
C/O NAI BLACK
107 S HOWARD ST
SPOKANE, WA 99201
PHONE: 623-1000
CONTACT: BRYAN WALKER

NO.	DATE	BY	REVISIONS
A	08/03/16	RMA	ORIGINAL PREPARATION

SCALE:	PROJ #: 13-1166
HORIZONTAL:	DATE: 08/03/16
1" = 100'	DRAWN: RMA
VERTICAL:	REVIEWED: TRW
N/A	

<input checked="" type="checkbox"/> CIVIL
<input type="checkbox"/> STRUCTURAL
<input type="checkbox"/> SURVEYING
<input type="checkbox"/> TRAFFIC
<input type="checkbox"/> PLANNING
<input type="checkbox"/> LANDSCAPE
<input type="checkbox"/> OTHER

WCE
WHIPPLE CONSULTING ENGINEERS
2528 NORTH SULLIVAN ROAD
SPOKANE VALLEY, WA 99216
PH: 509-893-2617, FAX: 509-929-0227

GUSTIN DITCH IMPROVEMENT PLANS
SWPPP COVER
40TH AVENUE
SPOKANE COUNTY, WA

SHEET C9.0

JOB NUMBER
13-1166

SE 1/4, SEC.33, T.25N., R.44E., W.M.
 SW 1/4, SEC.34, T.25N., R.44E., W.M.
 NE 1/4, SEC. 4, T.24N., R.44E., W.M.



EROSION & SEDIMENT CONTROL
GENERAL NOTES AND INFORMATION

- AN EROSION/SEDIMENT CONTROL (E.S.C.) PLAN IS REQUIRED FOR THIS PROJECT. IMPLEMENTATION OF THE E.S.C. PLAN, AND CONSTRUCTION, MAINTENANCE, AND UPGRADING OF THE E.S.C. FACILITIES ARE THE RESPONSIBILITY OF THE DEVELOPER UNTIL ALL CONSTRUCTION IS COMPLETED AND ACCEPTED BY SPOKANE COUNTY, OR UNTIL VEGETATION IS ESTABLISHED THROUGHOUT THE SITE, AND ACCEPTED BY SPOKANE COUNTY, WHICHEVER IS LATER.
- APPROVAL OF THE E.S.C. PLAN DOES NOT CONSTITUTE APPROVAL OF ANY OF THE PROPOSED ROAD, STORM DRAINAGE, GRADING OR UTILITY DESIGN ELEMENTS SHOWN ON THE E.S.C. PLAN.
- THE EROSION/SEDIMENT CONTROL MEASURES SHOWN ARE THE MINIMUM REQUIREMENTS FOR THE ANTICIPATED SITE CONDITIONS. THE CONTRACTOR SHALL INSPECT AND MAINTAIN THESE E.S.C. MEASURES DAILY, AND SHALL MAINTAIN AND UPGRADE THESE MEASURES AS NECESSARY TO PREVENT SEDIMENT-LADEN WATER FROM EITHER FLOWING OFF SITE, OR INTO NEW/EXISTING STORM DRAINAGE FACILITIES, SUCH AS DRYWELLS, CULVERTS, OR GRAVEL GALLERIES.
- GEOTEXTILE FABRIC IS TO BE PLACED ON THE RIMS, CATCH BASINS AND INLETS UNTIL SUCH TIME THAT THE VEGETATION ON THE SITE IS ESTABLISHED AND THE THREAT OF SEDIMENT DEPOSITION INTO THE DRAINAGE SYSTEM IS MITIGATED.
- THE SILT FENCES SHALL BE INSTALLED BY THE CONTRACTOR PRIOR TO OTHER SITE WORK, AND MAINTAINED THROUGHOUT THE DURATION OF CONSTRUCTION.
- THE CONTRACTOR IS RESPONSIBLE FOR INSTALLING ROCK CONSTRUCTION ENTRIES AT ANY AND ALL LOCATIONS USED TO ENTER OR EXIT THE PROJECT SITE. SEE DETAIL.
- THE CONTRACTOR IS RESPONSIBLE FOR DESIGNATING A LOCATION WHERE CONCRETE TRUCKS AND EQUIPMENT CAN BE WASHED OUT, NOT LOCATED NEAR OR DRAINING INTO A STORM DRAINAGE AREA.
- PROPERTY OWNER: **NAI BLACK - BRYAN WALKER**
 PERMIT APPLICANT: **WHIPPLE CONSULTING ENGINEERS, INC. 509-893-2617**
 CONTACT PERSON ON SITE: **TBD**
- PROJECT LOCATION: **NORTH OF 40TH AVENUE, IN SPOKANE COUNTY, WASHINGTON, IN SECTION 33, TOWNSHIP 25 N., RANGE 44 E. W.M.**
- PROJECT DESCRIPTION: **IMPROVEMENT OF 5 ACRES +/- OF AN EXISTING POND & DRAINAGE DITCH.**
- DESCRIPTION OF E.S.C. MEASURES: USE OF SILT FENCES AND SEDIMENTATION FILTERS. ALL E.S.C. MEASURES MENTIONED ABOVE ARE TEMPORARY AND WILL BE REMOVED AFTER SITE IS LANDSCAPED.
- EXISTING VEGETATION: **VACANT LAND WITH GRASS AND WEED COVER.**
- PLAN PREPARATION DATE: **AUGUST 2016**
- SOILS: **ALLUVIAL LEAN CLAY, SILT, OR SILTY SAND.**
- STABILIZATION OF DENUDED AREAS:**
 ANY DISTURBED AREAS, WHICH WOULD BE LEFT BARE FOR MORE THAN 7 DAYS AND ARE NOT INTENDED TO BE REWORKED WITHIN 30-45 DAYS SHALL BE SEEDDED WITH A FAST STARTING NATIVE DRYLAND GRASS SUCH AS ANNUAL RYE, OR APPROVED EQUAL, AT A RATE OF 60 lbs/ACRE.
- CONTROL OF POLLUTANTS:**
 ANY SPILLS WILL BE HANDLED ACCORDING TO D.O.E. AND D.O.H. GUIDELINES.
- LIMITS OF GRADING:**
 DURING THE COURSE OF CONSTRUCTION, THE AMOUNT OF DISTURBED AREA SHALL BE KEPT TO A MINIMUM AND SHALL BE LIMITED TO THE AREA SHOWN AS "LIMITS OF GRADING" ON THIS SHEET OF THE EROSION CONTROL PLANS.

MAINTENANCE

- THE CONTRACTOR SHALL BE RESPONSIBLE FOR INSTALLATION AND MAINTENANCE OF THE TEMPORARY E.S.C. MEASURES.
- SEDIMENT BARRIERS SHALL BE INSPECTED IMMEDIATELY AFTER EACH RUNOFF-PRODUCING RAINFALL AND AT LEAST DAILY DURING PROLONGED RAINFALL.
- NECESSARY REPAIRS TO BARRIERS OR REPLACEMENT OF FILTER FABRIC SHALL BE ACCOMPLISHED PROMPTLY.
- SEDIMENT DEPOSITS SHOULD BE REMOVED AFTER EACH RUNOFF-PRODUCING RAINFALL. DEPOSITS MUST BE REMOVED WHEN THE LEVEL OF DEPOSITION REACHES APPROXIMATELY 1/2 THE HEIGHT OF THE BARRIER.
- ANY SEDIMENT DEPOSITS REMAINING IN PLACE AFTER THE E.S.C. STRUCTURE IS NO LONGER REQUIRED SHALL BE DRESSED TO CONFORM TO THE EXISTING GRADE, PREPARED AND SEEDDED.
- ALL TEMPORARY AND PERMANENT E.S.C. PRACTICES SHALL BE MAINTAINED AND REPAIRED AS NEEDED TO ASSURE CONTINUED PERFORMANCE OF THEIR INTENDED FUNCTION.
- ALL TEMPORARY E.S.C. MEASURES SHALL BE REMOVED WITHIN 30 DAYS AFTER FINAL SITE STABILIZATION IS ACHIEVED OR AFTER THE TEMPORARY BMP'S ARE NO LONGER NEEDED. TRAPPED SEDIMENT SHALL BE REMOVED OR STABILIZED ON SITE. DISTURBED SOIL AREAS RESULTING FROM REMOVAL SHALL BE PERMANENTLY STABILIZED.
- THE CONTRACTOR SHALL BE RESPONSIBLE FOR CLEANING DIRT, MUD AND OTHER CONSTRUCTION DEBRIS WHICH MAY ACCUMULATE ON PAVED STREETS ADJACENT TO THE SITE AS A RESULT OF CONSTRUCTION ACTIVITY. CLEANING SHALL BE ON AN "AS NEEDED" BASIS USING SWEEPING AND WATER TO WASH THE CONSTRUCTION DEBRIS FROM THE STREET.
- ON-SITE DUST CONTROL SHALL BE ACCOMPLISHED BY USING WATER. APPLICATIONS OF WATER MAY BE REQUIRED SEVERAL TIMES PER DAY DURING CONSTRUCTION ACTIVITY.

E.S.C. STANDARD PLAN NOTES FROM APPENDIX 9A OF THE SPOKANE REGIONAL STORMWATER MANUAL


- THE FOLLOWING CONSTRUCTION SEQUENCE SHALL BE FOLLOWED IN ORDER TO BEST MINIMIZE THE POTENTIAL FOR EROSION AND SEDIMENTATION CONTROL PROBLEMS.
 - CLEAR AND GRUB SUFFICIENTLY FOR INSTALL OF TEMPORARY E.S.C. BMP'S;
 - INSTALL TEMPORARY E.S.C. BMP'S, CONSTRUCTING SEDIMENT TRAPPING BMP'S AS ONE OF THE FIRST STEPS PRIOR TO GRADING;
 - CLEAR, GRUB AND ROUGH GRADE FOR ROADS, TEMPORARY ACCESS POINTS AND UTILITY LOCATIONS;
 - STABILIZE ROADWAY APPROACHES AND TEMPORARY ACCESS POINTS WITH THE APPROPRIATE CONSTRUCTION ENTRY BMP;
 - CLEAR, GRUB AND GRADE INDIVIDUAL LOTS OR GROUPS OF LOTS;
 - TEMPORARILY STABILIZE, THROUGH RE-VEGETATION OR OTHER APPROPRIATE BMP'S, LOTS OR GROUPS OF LOTS IN SITUATIONS WHERE SUBSTANTIAL CUT OR FILL SLOPES ARE A RESULT OF THE SITE GRADING;
 - CONSTRUCT ROADS, BUILDINGS, PERMANENT STORMWATER FACILITIES. (I.E. INLETS, PONDS, U.I.C.FACILITIES, ETC.);
 - PROTECT ALL PERMANENT STORMWATER FACILITIES UTILIZING THE APPROPRIATE BMP'S;
 - INSTALL PERMANENT E.S.C. CONTROLS, WHEN APPLICABLE; AND,
 - REMOVE TEMPORARY E.S.C. CONTROLS WHEN;
- PERMANENT E.S.C. CONTROLS, WHEN APPLICABLE, HAVE BEEN COMPLETELY INSTALLED;
- ALL LAND-DISTURBING ACTIVITIES THAT HAVE THE POTENTIAL TO CAUSE EROSION AND SEDIMENTATION PROBLEMS HAVE CEASED; AND,
- VEGETATION HAD BEEN ESTABLISHED IN THE AREAS NOTED AS REQUIRING VEGETATION ON THE ACCEPTED E.S.C. PLAN ON FILE WITH THE LOCAL JURISDICTION.
- INSPECT ALL ROADWAYS, AT THE END OF EACH DAY, ADJACENT TO THE CONSTRUCTION ACCESS ROUTE. IF IT IS EVIDENT THAT SEDIMENT HAS BEEN TRACKED OFF SITE AND/OR BEYOND THE ROADWAY APPROACH, CLEANING IS REQUIRED.
- IF SEDIMENT REMOVAL IS NECESSARY PRIOR TO STREET WASHING, IT SHALL BE REMOVED BY SHOVELING OR PICKUP SWEEPING AND TRANSPORTED TO A CONTROLLED SEDIMENT DISPOSAL AREA.
- IF STREET WASHING IS REQUIRED TO CLEAN SEDIMENT TRACKED OFF SITE, ONCE SEDIMENT HAS BEEN REMOVED, STREET WASH WASTEWATER SHALL BE CONTROLLED BY PUMPING BACK ON-SITE OR OTHERWISE PREVENTED FROM DISCHARGING INTO SYSTEMS TRIBUTARY TO WATERS OF THE STATE.
- RESTORE CONSTRUCTION ACCESS ROUTE EQUAL TO OR BETTER THAN THE PRE-CONSTRUCTION CONDITION.
- RETAIN THE DUFF LAYER, NATIVE TOPSOIL, AND NATURAL VEGETATION IN AND UNDISTURBED STATE TO THE MAXIMUM EXTENT PRACTICAL.
- INSPECT SEDIMENT CONTROL BMP'S WEEKLY AT A MINIMUM, DAILY DURING A STORM EVENT, AND AFTER ANY DISCHARGE FROM THE SITE (STORMWATER OR NON-STORMWATER). THE INSPECTION FREQUENCY MAY BE REDUCED TO ONCE A MONTH IF THE SITE IS STABILIZED AND INACTIVE.
- CONTROL FUGITIVE DUST FROM CONSTRUCTION ACTIVITY IN ACCORDANCE WITH THE STATE AND/OR LOCAL AIR QUALITY CONTROL AUTHORITIES WITH JURISDICTION OVER THE PROJECT AREA.
- STABILIZE EXPOSED UNWORKED SOILS (INCLUDING STOCKPILES), WHETHER AT FINAL GRADE OR NOT WITHIN 10 DAYS DURING THE REGIONAL DRY SEASON (JULY 1 TO SEPTEMBER 30) AND WITHIN 5 DAYS DURING THE REGIONAL WET SEASON (OCTOBER 1 THRU JUNE 30). SOILS MUST BE STABILIZED AT THE END OF A SHIFT BEFORE A HOLIDAY WEEKEND IF NEEDED BASED ON THE WEATHER FORECAST. THE TIME LIMIT MAY ONLY BE ADJUSTED BY A LOCAL JURISDICTION WITH A "QUALIFIED LOCAL PROGRAM" IF IT CAN BE DEMONSTRATED THAT THE RECENT PRECIPITATION JUSTIFIES A DIFFERENT STANDARD AND MEETS THE REQUIREMENTS SET FORTH IN THE CONSTRUCTION STORMWATER GENERAL PERMIT.
- PROTECT INLETS, DRYWELLS, CATCH BASINS AND OTHER STORMWATER MANAGEMENT FACILITIES FROM SEDIMENT, WHETHER OR NOT FACILITIES ARE OPERABLE.
- KEEP ROADS ADJACENT TO INLETS CLEAN.
- INSPECT INLETS WEEKLY AT A MINIMUM AND DAILY FOR STORM EVENTS.
- CONSTRUCT STORMWATER CONTROL FACILITIES (DETENTION/RETENTION STORAGE POND OR SWALES) BEFORE GRADING BEGINS. THESE FACILITIES SHALL BE OPERABLE BEFORE THE CONSTRUCTION OF IMPERVIOUS SITE IMPROVEMENTS.
- STOCKPILE MATERIALS (SUCH AS TOPSOIL) ON SITE, KEEPING OFF OF ROADWAY AND SIDEWALKS.
- COVER, CONTAIN AND PROTECT ALL CHEMICALS, LIQUID PRODUCTS, PETROLEUM PRODUCT, AND NON-INERT WASTES PRESENT ON SITE FROM VANDALISM (SEE CHAPTER 173-304 W.A.C. FOR THE DEFINITION OF INERT WASTE), USE SECONDARY CONTAINMENT FOR ON-SITE FUELING TANKS.
- CONDUCT MAINTENANCE AND REPAIR OF HEAVY EQUIPMENT AND VEHICLES INVOLVING OIL CHANGES, HYDRAULIC SYSTEMS REPAIRS, SOLVENT AND DEGREASING OPERATIONS, FUEL TANK DRAIN DOWN AND REMOVAL, AND OTHER ACTIVITIES THAT MAY RESULT IN DISCHARGE OR SPILLAGE OF POLLUTANTS TO THE GROUND OR INTO STORMWATER RUNOFF USING SPILL RECONVENTION MEASURES, SUCH AS DRIP PANS. CLEAN ALL CONTAMINATED SURFACES IMMEDIATELY FOLLOWING ANY DISCHARGE OR SPILL INCIDENT. IF RAINING OVER EQUIPMENT OR VEHICLE, PERFORM EMERGENCY REPAIRS ON SITE USING TEMPORARY PLASTIC BENEATH THE VEHICLE.
- CONDUCT APPLICATION OF AGRICULTURAL CHEMICALS, INCLUDING FERTILIZERS AND PESTICIDES, IN SUCH A MANNER, AND AT APPLICATION RATES, THAT INHIBITS THE LOSS OF CHEMICALS INTO STORMWATER RUNOFF FACILITIES. AMEND MANUFACTURER'S RECOMMENDED APPLICATION RATES AND PROCEDURES TO MEET THIS REQUIREMENT, IF NECESSARY.
- INSPECT ON A REGULAR BASIS (AT A MINIMUM WEEKLY, AND DAILY DURING/AFTER A RUNOFF PRODUCING EVENT) AND MAINTAIN ALL EROSION AND SEDIMENT CONTROL BMP'S TO ENSURE SUCCESSFUL PERFORMANCE OF THE BMP'S. NOTE THAT INLET PROTECTIONS DEVICES SHALL BE CLEANED OR REMOVED AND REPLACE BEFORE SIX INCHES OF SEDIMENT CAN ACCUMULATE.
- REMOVE TEMPORARY E.S.C. BMP'S WITHIN 30 DAYS AFTER THE TEMPORARY BMP'S ARE NO LONGER NEEDED. PERMANENTLY STABILIZE AREA THAT ARE DISTURBED DURING REMOVAL PROCESS.

SRCAA GENERAL NOTES

- DUST EMISSIONS DURING DEMOLITION, CONSTRUCTION, AND EXCAVATION PROJECTS MUST BE CONTROLLED. THIS MAY REQUIRE THE USE OF WATER SPRAYS, TARPS, SPRINKLERS, OR SUSPENSION OF ACTIVITY DURING CERTAIN WEATHER CONDITIONS.
- MEASURES MUST BE TAKEN TO AVOID THE DEPOSITION OF DIRT AND MUD FROM UNPAVED SURFACES ONTO PAVED SURFACES. IF TRACKING OR SPILLS OCCUR ON PAVED SURFACES, MEASURES MUST BE TAKEN IMMEDIATELY TO CLEAN THESE SURFACES.
- DEBRIS GENERATED, AS A RESULT OF THIS PROJECT, MUST BE DISPOSED OF BY MEANS OTHER THAN BURNING (I.E., CONSTRUCTION WASTE, VEGETATIVE WASTE, ECT.).
- SPOKANE CLEAN AIR (SRCAA) STRONGLY RECOMMENDS THAT ALL TRAVELED SURFACES (I.E., INGRESS, EGRESS, PARKING AREAS, ACCESS ROADS, ECT.) BE PAVED AND KEPT CLEAN TO MINIMIZE DUST EMISSIONS.
- IF OBJECTIONABLE ODORS RESULT FROM THIS PROJECT, EFFECTIVE CONTROL APPARATUS AND MEASURES MUST BE TAKEN TO REDUCE ODORS TO A MINIMUM.
- SPECIAL ATTENTION SHOULD BE GIVEN TO PROPER MAINTENANCE OF DIESEL POWERED CONSTRUCTION EQUIPMENT TO REDUCE THE IMPACT OF DIESEL EXHAUST, A SUSPECTED CARCINOGEN.
- A NOTICE OF CONSTRUCTION AND APPLICATION FOR APPROVAL IS REQUIRED TO BE SUBMITTED AND APPROVED BY SRCAA PRIOR TO THE CONSTRUCTION, INSTALLATION, OR ESTABLISHMENT OF AN AIR POLLUTION SOURCE. THIS INCLUDES EMERGENCY GENERATORS RATED AT 500 HP(375 KW) OR HIGHER, NATURAL GAS HEATING EQUIPMENT UNITS RATED AT FOUR MMBTU/HOUR OR HIGHER (INPUT), AND HEATING EQUIPMENT UNITS FIRED WITH OTHER FUELS (E.G., DIESEL) RATED AT ONE MMBTU/HOUR (INPUT) OR HIGHER. CONTACT SPOKANE CLEAN AIR (SRCAA) FOR A NOTICE OF CONSTRUCTION APPLICATION.
- NOTICE OF INTENT MUST BE SUBMITTED TO SRCAA PRIOR TO ANY DEMOLITION PROJECT OR ASBESTOS PROJECT. AN ASBESTOS SURVEY MUST BE DONE BY AN HERA-ACCREDITED BUILDING INSPECTOR PRIOR TO THE DEMOLITION OR RENOVATION OF BUILDINGS TO DETERMINE IF ASBESTOS-CONTAINING MATERIAL IS PRESENT AT THE SITE. CONTACT SPOKANE CLEAN AIR (SRCAA) FOR A NOTICE OF INTENT APPLICATION.

NAVD - 88
 TBM S-5 OF THE SOUTH PONDEROSA SEWER PROJECT
 WITH AN ELEVATION OF 2005.87 (NAVD29) - 2009.67
 (NAVD88) WAS USED FOR THE VERTICAL DATUM FOR THIS
 MAP.

SCALE:		PROJ #:	13-1166	<input checked="" type="checkbox"/> CIVIL
HORIZONTAL:		DATE:	08/03/16	<input type="checkbox"/> STRUCTURAL
N/A		DRAWN:	RMA	<input type="checkbox"/> SURVEYING
VERTICAL:		REVIEWED:	TRW	<input type="checkbox"/> TRAFFIC
N/A				<input type="checkbox"/> PLANNING
				<input type="checkbox"/> LANDSCAPE
				<input type="checkbox"/> OTHER



GUSTIN DITCH IMPROVEMENT PLANS
SWPPP NOTES
40TH AVENUE
SPOKANE COUNTY, WA

PLANS
 NOT APPROVED
 BY AGENCY

Spokane County Permit No.:

Floodplain-Grading-

City of Spokane Valley Permit No.:

SUB-2015-0001
 FPD-2016-
 EGR-201X-XXXX

SHEET C9.1

JOB NUMBER
13-1166

P:\WCE_WORK\2013 WCE PROJECTS\2013-1166 Walker - Painted Hills\GUSTIN-C9.0 EROSION CONTROL.dwg, 10/13/2016 1:45:28 PM

SE 1/4, SEC.33, T.25N., R.44E., W.M.
 SW 1/4, SEC.34, T.25N., R.44E., W.M.
 NE 1/4, SEC. 4, T.24N., R.44E., W.M.



BMP C233: SILT FENCE

INFORMATION TAKEN FROM CHAPTER 7 OF THE EASTERN WASHINGTON STORMWATER MANAGEMENT MANUAL 2004 EDITION

PURPOSE: USE OF SILT FENCE REDUCES THE TRANSPORT OF COARSE SEDIMENT FROM A CONSTRUCTION SITE BY PROVIDING A TEMPORARY PHYSICAL BARRIER TO SEDIMENT AND REDUCING THE RUNOFF VELOCITIES OF OVERLAND FLOW. SEE FIGURE 7.3.20 OF THE EASTERN WASHINGTON STORMWATER MANUAL OR DETAIL BELOW FOR DETAILS ON SILT FENCE CONSTRUCTION.

CONDITIONS OF USE: SILT FENCE MAY BE USED DOWNSLOPE OF ALL DISTURBED AREAS. SILT FENCE IS NOT INTENDED TO TREAT CONCENTRATED FLOWS, NOR IS IT INTENDED TO TREAT SUBSTANTIAL AMOUNTS OF OVERLAND FLOW. ANY CONCENTRATED FLOWS MUST BE CONVEYED THROUGH THE DRAINAGE SYSTEM TO A SEDIMENT POND. THE ONLY CIRCUMSTANCE IN WHICH OVERLAND FLOW CAN BE TREATED SOLELY BY A SILT FENCE, RATHER THAN BY A SEDIMENT POND, IS WHEN THE AREA DRAINING TO THE FENCE IS ONE ACRE OR LESS AND FLOW RATES ARE LESS THAN 0.5 CFS.

SILT FENCES SHOULD NOT BE CONSTRUCTED IN STREAMS OR USED IN V-SHAPED DITCHES. THEY ARE NOT AN ADEQUATE METHOD OF SILT CONTROL FOR ANYTHING DEEPER THAN SHEET OR OVERLAND FLOW.

DESIGN AND INSTALLATION: DRAINAGE AREA OF 1 ACRE OR LESS OR IN COMBINATION WITH SEDIMENT BASIN IN A LARGER SITE.

MAXIMUM SLOPE STEEPNESS (NORMAL OR PERPENDICULAR TO FENCE LINE) 1:1.

MAXIMUM SHEET OR OVERLAND FLOW PATH LENGTH TO THE FENCE OF 100 FEET.

NO FLOWS GREATER THAN 0.5 CFS.

THE GEOTEXTILE USED SHALL MEET THE FOLLOWING STANDARDS. ALL GEOTEXTILE PROPERTIES LISTED BELOW ARE MINIMUM AVERAGE ROLL VALUES.

POLYMERIC MESH AOS (ASTM D4751)	0.60MM MAX. FOR SLIT WOVENS (#30 SIEVE), 0.30MM MAX. FOR ALL OTHER GEOTEXTILE TYPES (#50 SIEVE), 0.15MM MAX. FOR ALL FABRIC TYPES (#100 SIEVE).
WATER PERMITTIVITY (ASTM D4491)	0.02/SEC MIN.
GRAB TENSILE STRENGTH (ASTM D4632)	180 LBS. MIN. FOR EXTRA STRENGTH FABRIC, 100 LBS. MIN. FOR STANDARD STRENGTH FABRIC
GRAB TENSILE ELONGATION (ASTM D4632)	30% MAX.
ULTRAVIOLET RESISTANCE (ASTM D4335)	70% MIN.

STANDARD STRENGTH FABRICS SHALL BE SUPPORTED WITH WIRE MESH, CHICKEN WIRE, 2-INCH X 2-INCH, SAFETY FENCE, OR JUST MESH TO INCREASE THE STRENGTH OF FABRIC. SILT FENCE MATERIALS ARE AVAILABLE THAT HAVE SYNTHETIC MESH BACKING ATTACHED.

FILTER FABRIC MATERIAL SHALL CONTAIN ULTRAVIOLET RAY INHIBITORS AND STABILIZERS TO PROVIDE A MINIMUM OF SIX MONTHS OF EXPECTED USABLE CONSTRUCTION LIFE AT A TEMPERATURE RANGE OF 0°F. TO 120°F.

100 PERCENT BIODEGRADABLE SILT FENCE IS AVAILABLE THAT IS STRONG, LONG LASTING, AND CAN BE LEFT IN PLACE AFTER THE PROJECT IS COMPLETED, IF PERMITTED BY LOCAL REGULATIONS.

CONTRACTOR SHALL INSTALL AND MAINTAIN TEMPORARY SILT FENCES AT THE LOCATIONS SHOWN IN THE PLANS. THE SILT FENCE SHALL BE CONSTRUCTED IN THE AREAS OF CLEARING, GRADING, OR DRAINAGE PRIOR TO STARTING THOSE ACTIVITIES. A SILT FENCE SHALL NOT BE CONSIDERED TEMPORARY IF THE SILT FENCE MUST OPERATE BEYOND THE LENGTH OF THE CONTRACT. THE SILT FENCE SHALL PREVENT SOIL CARRIED BY RUNOFF WATER FROM GOING BENEATH, THROUGH, OR OVER THE TOP OF THE SILT FENCE, BUT SHALL ALLOW WATER TO PASS THROUGH THE FENCE.

THE MINIMUM HEIGHT OF THE TOP OF SILT FENCE SHALL BE 2 FEET AND THE MAXIMUM SHALL BE 2.5 FEET ABOVE THE ORIGINAL GROUND SURFACE.

DESIGN AND INSTALLATION: (CONTINUED)

THE GEOTEXTILE SHALL BE SEWN TOGETHER AT THE POINT OF MANUFACTURE, OR AT AN APPROVED LOCATION AS DETERMINED BY THE ENGINEER, TO FORM GEOTEXTILE LENGTHS AS REQUIRED. ALL SEWN SEAMS SHALL BE LOCATED AT A SUPPORT POST. ALTERNATIVELY, TWO SECTIONS OF SILT FENCE CAN BE OVERLAPPED, PROVIDED THE CONTRACTOR CAN DEMONSTRATE, TO THE SATISFACTION OF THE ENGINEER, THAT THE OVERLAP IS LONG ENOUGH AND THAT THE ADJACENT FENCE SECTIONS ARE CLOSE ENOUGH TOGETHER TO PREVENT SILT LAIDEN WATER FROM ESCAPING THROUGH THE FENCE AT THE OVERLAP.

THE GEOTEXTILE SHALL BE ATTACHED ON THE UP-SLOPE SIDE OF THE POSTS AND SUPPORT SYSTEM WITH STAPLES, WIRE, OR IN ACCORDANCE WITH THE MANUFACTURER'S RECOMMENDATIONS. THE GEOTEXTILE SHALL BE ATTACHED IN A MANNER THAT REDUCES THE POTENTIAL FOR GEOTEXTILE TEARING AT THE STAPLES, WIRE, OR OTHER CONNECTION DEVICE. SILT FENCE BACKUP SUPPORT FOR THE GEOTEXTILE IN THE FORM OF A WIRE OR PLASTIC MESH IS DEPENDENT ON THE PROPERTIES OF THE GEOTEXTILE SELECTED FOR USE. IF WIRE OR PLASTIC BACK-UP MESH IS USED, THE MESH SHALL BE FASTENED SECURELY TO THE UP-SLOPE OF THE POSTS WITH THE GEOTEXTILE BEING UP-SLOPE OF THE MESH BACK SUPPORT.

THE GEOTEXTILE AT THE BOTTOM OF THE FENCE SHALL BE BURIED IN A TRENCH TO A MINIMUM DEPTH OF 4" BELOW THE GROUND SURFACE. THE TRENCH SHALL BE BACKFILLED AND THE SOIL TAMPED IN PLACE OVER THE BURIED PORTION OF THE GEOTEXTILE, SUCH THAT NO FLOW CAN PASS BENEATH THE FENCE AND SCOURING CAN NOT OCCUR. WHEN WIRE OR POLYMERIC BACK-UP SUPPORT MESH IS USED, THE WIRE OR POLYMERIC MESH SHALL EXTEND INTO THE TRENCH A MINIMUM OF 3".

THE FENCE POSTS SHALL BE PLACED OR DRIVEN A MIN. OF 18". A MIN. DEPTH OF 12" IS ALLOWED IF TOPSOIL OR OTHER SOFT SUBGRADE SOIL IS NOT PRESENT AND A MIN. DEPTH OF 18" CANNOT BE REACHED. FENCE POST DEPTHS SHALL BE INCREASED 6" IF THE FENCE IS LOCATED ON SLOPES PF 3:1 OR STEEPER AND THE SLOPE IS PERPENDICULAR TO THE FENCE. IF REQUIRED POST DEPTHS CANNOT BE OBTAINED, THE POSTS SHALL BE ADEQUATELY SECURED BY BRACING OR GUYING TO PREVENT OVERTURNING OF THE FENCE DUE TO SEDIMENT LOADING.

SILT FENCES SHALL BE LOCATED ON CONTOUR AS MUCH AS POSSIBLE, EXCEPT AT THE ENDS OF THE FENCE, WHERE THE FENCE SHALL BE TURNED UPHILL SUCH THAT THE SILT FENCE CAPTURES THE RUNOFF WATER AND PREVENTS WATER FROM FLOWING AROUND THE END OF THE FENCE.

IF THE FENCE MUST CROSS CONTOURS, WITH THE EXCEPTION OF THE END OF THE FENCE, GRAVEL CHECK DAMS PLACED PERPENDICULAR TO THE BACK OF THE FENCE SHALL BE USED TO MINIMIZE CONCENTRATED FLOW AND EROSION ALONG THE BACK OF THE FENCE. THE GRAVEL CHECK DAMS SHALL BE APPROXIMATELY 1' DEEP AT THE BACK OF THE FENCE. IT SHALL BE CONTINUED PERPENDICULAR TO THE FENCE AT THE SAME ELEVATION UNTIL THE TOP OF THE CHECK DAM INTERCEPTS THE GROUND SURFACE BEHIND THE FENCE. THE GRAVEL CHECK DAMS SHALL CONSIST OF CRUSHED SURFACING TOP COURSE, GRAVEL BACKFILL FOR WALLS, OR SHOULDER BALLAST. THE GRAVEL CHECK DAMS SHALL BE LOCATED EVERY 10' ALONG THE FENCE WHERE THE FENCE MUST CROSS THE CONTOURS. THE SLOPE OF THE FENCE LINE WHERE THE CONTOURS MUST BE CROSSED SHALL NOT BE STEEPER THAN 3:1

WOOD, STEEL OR EQUIVALENT POSTS SHALL BE USED. WOOD POSTS SHALL HAVE MINIMUM DIMENSIONS OF 2"x2"x3" MIN. LENGTH, AND SHALL BE FREE OF DEFECTS SUCH AS KNOTS, SPLITS, OR GOUGES. STEEL POSTS SHALL CONSIST OF EITHER SIZE NO. 6 REBAR OR LARGER, ASTM A 120 STEEL PIPE WITH A MIN. DIAMETER, OR 1-INCH, U, T, L, OR C SHAPE STEEL POSTS WITH A MIN. WEIGHT OF 1.35 LBS./FT. OR OTHER STEEL POSTS HAVING EQUIVALENT STRENGTH AND BENDING RESISTANCE TO THE POST SIZES LISTED. THE SPACING OF THE SUPPORTS POSTS SHALL BE A MAXIMUM OF 6'.

FENCE BACK-UP SUPPORT, IF USED, SHALL CONSIST OF STEEL WIRE WITH A MAX. MESH SPACING OF 2', OR A PREFABRICATED POLYMERIC MESH. THE STRENGTH OF WIRE OR POLYMERIC MESH SHALL BE EQUIVALENT TO OR GREATER THAN 180 LBS. GRAB TENSILE STRENGTH. THE POLYMERIC MESH MUST BE AS RESISTANT TO ULTRAVIOLET RADIATION AS THE GEOTEXTILE IT SUPPORTS.

SILT FENCE INSTALLATION USING THE SLICING METHOD SPECIFICATION DETAILS FOLLOW.

THE BASE OF BOTH END POSTS MUST BE AT LEAST 2-4" ABOVE THE TOP OF THE SILT FENCE FABRIC ON THE MIDDLE POSTS FOR DITCH CHECKS TO DRAIN PROPERLY. USE A HAND LEVEL OR STRING LEVEL, IF NECESSARY, TO MARK BASE POINTS BEFORE INSTALLATION.

INSTALL POSTS 3-4' APART IN CRITICAL RETENTION AREAS, AND 6-7' APART IN STANDARD APPLICATIONS.

INSTALL POSTS 24" DEEP ON THE DOWNSTREAM SIDE OF THE SILT FENCE, AND AS CLOSE AS POSSIBLE TO THE FABRIC. ENABLING POSTS TO SUPPORT THE FABRIC FROM THE UPSTREAM WATER PRESSURE.

INSTALL POSTS WITH NIPPLES FACING AWAY FROM THE SILT FENCE FABRIC.

ATTACH THE FABRIC TO EACH POST WITH THREE TIES, ALL SPACED WITH THE TOP 8" OF THE FABRIC. ATTACH EACH TIE DIAGONALLY 45 DEGREES THROUGH THE FABRIC, WITH EACH PUNCTURE AT LEAST 1 INCH VERTICALLY APART, IN ADDITION, EACH TIE SHOULD BE POSITIONED TO HANG ON A POST NIPPLE WHEN TIGHTENING TO PREVENT SAGGING.

WRAP APPROXIMATELY 6 INCHES OF FABRIC AROUND THE END POSTS AND SECURE WITH 3 TIES.

NO MORE THAN 24" OF A 36" FABRIC IS ALLOWED ABOVE GROUND LEVEL.

THE ROPE LOCK SYSTEM MUST BE USED IN ALL DITCH CHECK APPLICATIONS.

THE INSTALLATION SHOULD BE CHECKED AND CORRECTED FOR ANY DEVIATION BEFORE COMPACTION. USE A FLAT-BLADED SHOVEL TO TUCK FABRIC DEEPER INTO THE GROUND IF NECESSARY.

COMPACTION IS VITALLY IMPORTANT FOR EFFECTIVE RESULTS. COMPACT THE SOIL IMMEDIATELY NEXT TO THE SILT FENCE WITH THE FRONT WHEEL OF A TRACTOR, SKID STEER, OR ROLLER EXERTING 60 PSI, COMPACT THE UPSTREAM SIDE FIRST AND THEN EACH SIDE TWICE FOR A TOTAL OF FOUR TRIPS

ANY DAMAGE SHALL BE REPAIRED IMMEDIATELY.

IF CONCENTRATED FLOWS ARE EVIDENT UPHILL OF THE FENCE, THEY MUST BE INTERCEPTED AND CONVEYED TO A SEDIMENT POND.

IT IS IMPORTANT TO CHECK THE UPHILL SIDE OF THE FENCE FOR SIGNS OF THE FENCE CLOGGING AND ACTING AS A BARRIER TO FLOW AND THEN CAUSING CHANNELIZATION OF THE FLOWS PARALLEL TO THE FENCE, IF THIS OCCURS, REPLACE THE FENCE OR REMOVE THE TRAPPED SEDIMENT.

SEDIMENT DEPOSITS SHALL EITHER BE REMOVED WHEN THE DEPOSIT REACHES APPROXIMATELY ONE-THIRD THE HEIGHT OF THE SILT FENCE, OR A SECOND SILT FENCE INSTALLED.

IF THE FILTER FABRIC OR GEOTEXTILE HAS DETERIORATED DUE TO ULTRAVIOLET BREAKDOWN, IT SHALL BE REPLACED.

BMP C105: STABILIZED CONSTRUCTION ENTRANCE

INFORMATION TAKEN FROM CHAPTER 7 OF THE EASTERN WASHINGTON STORMWATER MANAGEMENT MANUAL 2004 EDITION

PURPOSE: CONSTRUCTION ENTRANCES ARE STABILIZED TO REDUCE THE AMOUNT OF SEDIMENT TRANSPORTED ONTO PAVED ROADS BY VEHICLES OR EQUIPMENT BY CONSTRUCTING A STABILIZED PAD OF QUARRY SPALLS AT ENTRANCES TO CONSTRUCTION SITES.

CONDITIONS OF USE: CONSTRUCTION ENTRANCES SHALL BE STABILIZED WHEREVER TRAFFIC WILL BE LEAVING A CONSTRUCTION SITE AND TRAVELING ON PAVED ROADS OR OTHER PAVED AREAS WITHIN 1,000 FEET OF THE SITE.

ON LARGE COMMERCIAL, HIGHWAY, AND ROAD PROJECTS, THE DESIGNER AND OR CONTRACTOR SHOULD INCLUDE ENOUGH MATERIALS IN THE CONTRACT TO ALLOW FOR ADDITIONAL STABILIZED ENTRANCES NOT SHOWN IN THE INITIAL CONSTRUCTION SWPPP. IT IS DIFFICULT TO DETERMINE EXACTLY WHERE ACCESS TO THESE PROJECTS WILL TAKE PLACE; ADDITIONAL MATERIALS WILL ENABLE THE CONTRACTOR TO INSTALL THEM WHERE NEEDED.

DESIGN AND INSTALLATION: SEE FIGURE 7.3.2 OF THE EASTERN WATER STORMWATER MANAGEMENT MANUAL OR DETAIL BELOW.

THE SURFACE MATERIAL SHALL BE 4"-8" QUARRY SPALLS, SMALLER CRUSHED ROCK SUCH AS BASE COURSE MAY BE APPROPRIATE IN SOME SITUATIONS BUT, SINCE IT IS MORE LIKELY TO BE TRACKED OFF-SITE, MUST BE PROVIDED BY THE LOCAL JURISDICTION.

A SEPARATION GEOTEXTILE SHALL BE PLACED UNDER THE SPALLS TO PREVENT FINE SEDIMENT FROM PUMPING UP INTO THE ROCK PAD. THE GEOTEXTILE SHALL MEET THE FOLLOWING STANDARDS:

GRAB TENSILE STRENGTH (ASTM D4751)	200 PSI MIN.
GRAB TENSILE ELONGATION (ASTM D4632)	30% MAX.
MULLEN BURST STRENGTH (ASTM D3786-80A)	400 PSI MIN.
AOS (ASTM D4751)	20-45 (U.S. STANDARD SIEVE SIZE)

IF SITE CONDITIONS DO NOT WARRANT THE USE OF GEOTEXTILE, IT IS NOT REQUIRED.

MAINTENANCE STANDARDS: IF QUARRY SPALLS (OR HOG FUEL) SHALL BE ADDED IF THE PAD IS NO LONGER IN ACCORDANCE WITH THE SPECIFICATIONS.


IF THE ENTRANCE IS NOT PREVENTING SEDIMENT FROM BEING TRACKED ONTO PAVEMENT, THEN ALTERNATIVE MEASURES TO KEEP THE STREETS FREE OF SEDIMENT SHALL BE USED. THIS MAY INCLUDE STREET SWEEPING, AN INCREASE IN THE DIMENSIONS OF THE ENTRANCE, OR THE INSTALLATION OF A WHEEL WASH.

ANY SEDIMENT THAT IS TRACKED ONTO PAVEMENT SHALL BE REMOVED BY SHOVELING OR STREET SWEEPING. THE SEDIMENT COLLECTED BY SWEEPING SHALL BE REMOVED OR STABILIZED ON SITE. THE PAVEMENT SHALL NOT BE CLEANED BY WASHING DOWN THE STREET, EXCEPT WHEN SWEEPING IS INEFFECTIVE AND THERE IS A THREAT TO PUBLIC SAFETY. IF IT IS NECESSARY TO WASH THE STREETS, THE CONSTRUCTION OF A SMALL SUMP SHALL BE CONSIDERED. THE SEDIMENT WOULD THEN BE WASHED INTO THE SUMP WHERE IT CAN BE CONTROLLED.


ANY QUARRY SPALLS THAT ARE LOOSENED FROM THE PAD, WHICH END UP ON THE ROADWAY SHALL BE REMOVED IMMEDIATELY.

IF VEHICLES ARE ENTERING OR EXITING THE SITE AT POINTS OTHER THAN THE CONSTRUCTION ENTRANCE(S), FENCING (SEE BMPs C103 AND C104) SHALL BE INSTALLED TO CONTROL TRAFFIC.

UPON PROJECT COMPLETION AND SITE STABILIZATION, ALL CONSTRUCTION ACCESSSES INTENDED AS PERMANENT ACCESS FOR MAINTENANCE SHALL BE PERMANENTLY STABILIZED.



ROCK CONSTRUCTION ENTRY
 NOT TO SCALE



SILT FENCE DETAIL
 NOT TO SCALE

MAINTENANCE STANDARDS:

SCALE:		PROJ #:	13-1166	X CIVIL STRUCTURAL SURVEYING TRAFFIC PLANNING LANDSCAPE OTHER
HORIZONTAL:		DATE:	08/03/16	
VERTICAL:		DRAWN:	RMA	WCE WHIPPLE CONSULTING ENGINEERS 2528 NORTH SULLIVAN ROAD SPOKANE VALLEY, WA 99216 PH: 509-893-2617 FAX: 509-829-4227
NO. DATE BY		REVIEWED:	TRW	
ORIGINAL PREPARATION				
REVISIONS				

PLANS NOT APPROVED BY AGENCY

Spokane County Permit No.:

Floodplain-Grading-

City of Spokane Valley Permit No.:

SUB-2015-0001
 FPD-2016-
 EGR-201X-XXXX

10/13/16

GUSTIN DITCH IMPROVEMENT PLANS
 SWPPP BMPs
 40TH AVENUE
 SPOKANE COUNTY, WA

SHEET C9.2

JOB NUMBER 13-1166

NAVD - 88

TBM S-5 OF THE SOUTH PONDEROSA SEWER PROJECT WITH AN ELEVATION OF 2005.87 (NAVD29) - 2009.67 (NAVD88) WAS USED FOR THE VERTICAL DATUM FOR THIS MAP.

P:\WCE\WORK\2013 WCE PROJECTS\2013-1166 Walker - Painted Hills\GCD\DWG\GUSTIN-C9.0 EROSION CONTROL.dwg, 10/13/2016 1:45:32 PM

SE ¹/₄, SEC.33, T.25N., R.44E., W.M.
 SW ¹/₄, SEC.34, T.25N., R.44E., W.M.
 NE ¹/₄, SEC. 4, T.24N., R.44E., W.M.

UNDERGROUND SERVICE ALERT
 ONE-CALL NUMBER
811
 CALL TWO BUSINESS DAYS BEFORE YOU DIG

BMP C220: STORM DRAIN INLET PROTECTION

INFORMATION TAKEN FROM CHAPTER 7 OF THE EASTERN WASHINGTON STORMWATER MANAGEMENT MANUAL 2004 EDITION

PURPOSE: TO PREVENT COARSE SEDIMENT FROM ENTERING DRAINAGE SYSTEMS PRIOR TO PERMANENT STABILIZATION OF THE DISTURBED AREA

CONDITIONS OF USE: WHERE STORM DRAIN INLETS ARE TO BE MADE OPERATIONAL BEFORE PERMANENT STABILIZATION OF THE DISTURBED DRAINAGE AREA, PROTECTION SHOULD BE PROVIDED FOR ALL STORM DRAIN INLETS DOWNSLOPE AND WITHIN 500 FEET OF A DISTURBED OR CONSTRUCTION AREA, UNLESS THE RUNOFF THAT ENTERS THE CATCH BASIN WILL BE CONVEYED TO A SEDIMENT POND OR TRAP. INLET PROTECTION MAY BE USED ANYWHERE TO PROTECT THE DRAINAGE SYSTEM. IT IS LIKELY THAT THE DRAINAGE SYSTEM WILL REQUIRE CLEANING.

TABLE 7.3.9 (IN THE EASTERN WASHINGTON STORMWATER MANAGEMENT MANUAL) LISTS SEVERAL OPTIONS FOR INLET PROTECTION. ALL OF THE METHODS FOR STORM DRAIN INLET PROTECTION ARE PRONE TO PLUGGING AND REQUIRE A HIGH FREQUENCY OF MAINTENANCE. DRAINAGE AREAS SHOULD BE LIMITED TO 1 ACRE OR LESS. EMERGENCY OVERFLOWS MAY BE REQUIRED WHERE STORMWATER PONDING WOULD CAUSE A HAZARD. IF AN EMERGENCY OVERFLOW IS PROVIDED, ADDITIONAL END-OF-PIPE TREATMENT MAY BE REQUIRED.

DESIGN AND INSTALLATION: EXCAVATED DROP INLET PROTECTION - AN EXCAVATED IMPOUNDMENT AROUND THE STORM DRAIN. SEDIMENT SETTLES OUT OF THE STORMWATER PRIOR TO ENTERING THE STORM DRAIN.

DEPTH 1-2 FT AS MEASURED FROM THE CREST OF THE INLET STRUCTURE.

SIDE SLOPES OF EXCAVATION NO STEEPER THAT 2:1

MINIMUM VOLUME OF EXCAVATION 35 CUBIC YARDS

SHAPE THE BASIN TO FIT THE SITE WITH THE LONGEST DIMENSION ORIENTED TOWARD THE LONGEST INFLOW AREA.

INSTALL PROVISIONS FOR DRAINING TO PREVENT STANDING WATER PROBLEMS.

CLEAR THE AREA OF ALL DEBRIS.

GRADE THE APPROACH TO THE INLET UNIFORMLY.

DRILL WEEP HOLES INTO THE SIDES OF THE INLET.

PROTECT WEEP HOLES WITH SCREEN WIRE AND WASHED AGGREGATE.

SEAL WEEP HOLES WHEN REMOVING STRUCTURE AND STABILIZING AREA.

IT MAY BE NECESSARY TO BUILD A TEMPORARY DIKE TO THE DOWN SLOPE STRUCTURE TO PREVENT BYPASS FLOW.

BLOCK AND GRAVEL CURB FILTER - A BARRIER FORMED AROUND THE STORM DRAIN INLET WITH STANDARD CONCRETE BLOCKS AND GRAVEL. SEE FIGURE 4.15 IN THE EASTERN WASHINGTON STORMWATER MANAGEMENT MANUAL.

HEIGHT 1-2 FT ABOVE THE INLET.

RECESS THE FIRST ROW 2" INTO THE GROUND FOR STABILITY.

SUPPORT SUBSEQUENT COURSES BY PLACING A 2X4 THROUGH THE BLOCK OPENING.

DO NOT USE MORTAR.

LAY SOME BLOCKS IN THE BOTTOM ROW ON THEIR SIDE FOR DEWATERING THE POOL.

PLACE HARDWARE CLOTH OR COMPARABLE WIRE MESH WITH 1/2" OPENINGS OVER ALL BLOCK OPENINGS.

PLACE GRAVEL JUST BELOW THE TOP OF BLOCKS ON SLOPES 2:1 OR FLATTER.

AN ALTERNATIVE DESIGN IN A GRAVEL DONUT.

INLET SLOPE OF 3:1.

OUTLET SLOPE OF 2:1.

1-FOOT WIDE LEVEL STONE AREA BETWEEN THE STRUCTURE AND THE INLET.

INLET SLOPES STONES 3" IN DIAMETER OR LARGER.

OUTLET SLOPE USE GRAVEL 1/2" TO 3/4" AT A MINIMUM THICKNESS OF 1 FOOT.

GRAVEL AND WIRE MESH INLET - A GRAVEL BARRIER PLACED OVER TOP OF THE INLET. THIS STRUCTURE DOES NOT PROVIDE AN OVERFLOW

HARDWARE CLOTH OR COMPARABLE WIRE MESH WITH 1/2" OPENINGS.

COARSE AGGREGATE.

HEIGHT 1-FOOT OR MORE, 18" WIDER THAN INLET ON ALL SIDES.

PLACE WIRE MESS OVER THE DROP INLET SO THAT THE WIRE EXTENDS A MINIMUM OF 1-FOOT BEYOND EACH SIDE OF THE INLET STRUCTURE.

IF MORE THAN ONE STRIP OF MESH IN NECESSARY, OVERLAP THE STRIPS.

PLACE COARSE AGGREGATE OVER THE WIRE MESH.

THE DEPTH OF THE GRAVEL SHOULD BE AT LEAST 12" OVER THE ENTIRE INLET OPENING AND EXTEND AT LEAST 18" ON ALL SIDES.

DESIGN AND INSTALLATION CONTINUED:

CATCH BASIN FILTERS - INSERTS SHOULD BE DESIGNED BY THE MANUFACTURER FOR USE AT CONSTRUCTION SITES. THE LIMITED SEDIMENT STORAGE CAPACITY INCREASES THE AMOUNT OF INSPECTION AND MAINTENANCE REQUIRED, WHICH MAY BE DAILY FOR HEAVY SEDIMENT LOADS. THE MAINTENANCE REQUIREMENTS CAB BE REDUCED BY COMBINING A CATCH BASIN FILTER WITH ANOTHER TYPE OF INLET PROTECTION. THIS TYPE OF INLET PROTECTION PROVIDES FLOW BYPASS WITHOUT OVERFLOW AND THEREFORE MAY BE A BETTER METHOD FOR INLETS LOCATED ALONG ACTIVE RIGHTS-OF-WAY.

5 CUBIC FEET OF STORAGE

DEWATERING PROVISIONS

HIGH-FLOW BYPASS THAT WILL NOT CLOG UNDER NORMAL USE AT A CONSTRUCTION SITE.

THE CATCH BASIN FILTER IS INSERTED IN THE CATCH BASIN JUST BELOW THE GRATING.

CURB INLET PROTECTION WITH WOODED WEIR - BARRIER FORMED AROUND CURB INLET WITH A WOODEN FRAME AND GRAVEL.

WIRE MESH WITH 1/2" OPENINGS.

EXTRA STRENGTH FILTER FABRIC TO THE FRAME.

PILE COARSE WASHED AGGREGATE AGAINST THE WIRE/FABRIC.

PLACE WEIGHT ON FRAME ANCHORS.

BLOCK AND GRAVEL CURB INLET PROTECTION - BARRIER FORMED AROUND AN INLET WITH CONCRETE BLOCKS AND GRAVEL. SEE FIGURE 7.3.16 OF THE EASTERN WASHINGTON STORMWATER MANAGEMENT MANUAL.

WIRE MESH WITH 1/2" OPENINGS.

PLACE 2 CONCRETE BLOCKS ON THEIR SIDES ABUTTING THE CURB AT EITHER SIDE OF THE INLET OPENING. THESE ARE SPACER BLOCKS.

PLACE A 2X4 STUD THROUGH THE OUT HOLES OF EACH SPACER BLOCK TO ALIGN THE FRONT BLOCKS.

PLACE BLOCKS ON THEIR SIDES ACROSS THE FRONT OF THE INLET AND ABUTTING THE SPACER BLOCKS.

PLACE WIRE MESH OVER THE OUTSIDE VERTICAL FACE.

PILE COARSE AGGREGATE AGAINST THE WIRE TO THE TOP OF THE BARRIER.

CURB AND GUTTER SEDIMENT BARRIER - SANDBAG OR ROCK BERM (RIPRAP AND AGGREGATE) 3 FEET HIGH AND 3 FEET WIDE IN A HORSESHOE SHAPE. SEE FIGURE 7.3.17 OF THE EASTERN WASHINGTON STORMWATER MANAGEMENT MANUAL.

CONSTRUCT HORSESHOE SHAPED BERM, FACED WITH COARSE AGGREGATE IF USING RIPRAP, 3 FEET HIGH AND 3 FEET WIDE, AT LEAST 2 FEET FROM THE INLET.

CONSTRUCT A HORSESHOE SHAPED SEDIMENTATION TRAP ON THE OUTSIDE OF THE BERM SIZED TO SEDIMENT TRAP STANDARDS FOR PROTECTING A CULVERT INLET.

MAINTENANCE STANDARDS: CATCH BASIN FILTERS SHOULD BE INSPECTED FREQUENTLY, ESPECIALLY AFTER STORM EVENTS. IF THE INSERT BECOMES CLOGGED, IT SHOULD BE CLEANED OR REPLACED.

FOR SYSTEMS USING STONE FILTERS: IF THE STONE FILTER BECOMES CLOGGED WITH SEDIMENT, THE STONES MUST BE PULLED AWAY FROM THE INLET AND CLEANED OR REPLACED. SINCE CLEANING OF GRAVEL AT A CONSTRUCTION SITE MAY BE DIFFICULT, AN ALTERNATIVE APPROACH WOULD BE USED TO USE THE CLOGGED STONE AS FILL AND PUT FRESH STONE AROUND THE INLET.

DO NOT WASH SEDIMENT INTO STORM DRAINS WHILE CLEANING. SPREAD ALL EXCAVATED MATERIAL EVENLY OVER THE SURROUNDING LAND AREA OR STOCKPILE AND STABILIZE AS APPROPRIATE.

BMP C140: DUST CONTROL

INFORMATION TAKEN FROM CHAPTER 7 OF THE EASTERN WASHINGTON STORMWATER MANAGEMENT MANUAL 2004 EDITION

PURPOSE: DUST CONTROL PREVENTS WIND TRANSPORT OF DUST FROM DISTURBED SOIL SURFACES ONTO ROADWAYS, DRAINAGE WAYS, AND SURFACE WATERS. WIND EROSION IS A SIGNIFICANT CAUSE OF SOIL MOVEMENT FROM CONSTRUCTION SITES IN EASTERN WASHINGTON. ALTHOUGH WIND EROSION CAN CONTRIBUTE TO WATER QUALITY IMPACTS, DUST CONTROL IS REGULATED IN SOME AREAS OF EASTERN WASHINGTON PRIMARILY THROUGH LOCAL AIR QUALITY AUTHORITIES. WHERE SUCH AN ENTITY EXISTS, CONTACT THE LOCAL AIR QUALITY AUTHORITY FOR APPROPRIATE AND REQUIRED BMPs FOR DUST CONTROL TO IMPLEMENT AT YOUR PROJECT SITE.

CONDITIONS OF USE: IN AREAS (INCLUDING ROADWAYS) SUBJECT TO SURFACE AND AIR MOVEMENT OF DUST WHERE ON-SITE AND OFF-SITE IMPACTS TO ROADWAYS, DRAINAGE WAYS, OR SURFACE WATERS ARE LIKELY.

DESIGN AND INSTALLATION: CONTACT YOUR LOCAL AIR POLLUTION CONTROL AUTHORITY FOR GUIDANCE AND TRAINING ON OTHER DUST CONTROL MEASURES. COMPLIANCE WITH THE LOCAL AIR POLLUTION CONTROL AUTHORITY CONSTITUTES COMPLIANCE WITH THIS BMP.

WATER APPLIED TO CONSTRUCTION SITES FOR DUST CONTROL MUST NOT LEAVE THE SITE AS SURFACE RUNOFF.

SEE ALSO "TECHNIQUES FOR DUST PREVENTION AND SUPPRESSION," ECOLOGY PUBLICATION NUMBER 96-433, REVISED APRIL 2002.

TECHNIQUES THAT CAN BE USED FOR CONSTRUCTION PROJECTS INCLUDE:

VEGETATE OR MULCH AREAS THAT WILL NOT RECEIVE VEHICLE TRAFFIC. IN AREAS WHERE PLANTING, MULCHING, OR PAVING IS IMPRACTICAL, APPLY GRAVEL OR LANDSCAPING ROCK.

LIMIT DUST GENERATION BY CLEARING ONLY THOSE AREAS WHERE IMMEDIATE ACTIVITY WILL TAKE PLACE, LEAVING THE REMAINDER AREA(S) IN THE ORIGINAL CONDITION, IF STABLE. MAINTAIN THE ORIGINAL GROUND COVER AS LONG AS PRACTICAL.

CONSTRUCT NATURAL OR ARTIFICIAL WINDBREAKS OR WINDSCREENS. THESE MAY BE DESIGNED AS ENCLOSURES FOR SMALL DUST SOURCES.

SPRINKLE THE SITE WITH WATER UNTIL THE SURFACE IS WET. REPEAT AS NEEDED, TO PREVENT CARRYOUT OF MUD ONTO STREET, REFER TO STABILIZED CONSTRUCTION ENTRANCE (BMP C105).

IRRIGATION WATER CAN BE USED FOR DUST CONTROL. IRRIGATION SYSTEMS SHOULD BE INSTALLED AS A FIRST STEP ON SITES WHERE DUST CONTROL IS A CONCERN.

SPRAY EXPOSED SOIL AREAS WITH A DUST PALLIATIVE, FOLLOWING THE MANUFACTURER'S INSTRUCTIONS AND CAUTIONS REGARDING ANDLING AND APPLICATION. USED OIL IS PROHIBITED FROM USE AS A DUST SUPPRESSANT. LOCAL GOVERNMENTS MAY APPROVE OTHER DUST PALLIATIVES SUCH AS CALCIUM CHLORIDE OR PAM.

PAM (BMPC126) ADDED TO WATER AT A RATE OF 0.5LBS PER 1,000 GALLONS OF WATER PER ACRE AND APPLIED FROM A WATER TRUCK IS MORE EFFECTIVE THAN WATER ALONE. THE IS DUE TO THE INCREASED INFILTRATION OF WATER INTO THE SOIL AND REDUCED EVAPORATION. IN ADDITION, SMALL SOIL PARTICLES ARE BONDED TOGETHER AND ARE NOT AS EASILY TRANSPORTED BY WIND. ADDING PAM MAY ACTUALLY REDUCE THE QUANTITY OF WATER NEEDED FOR DUST CONTROL, ESPECIALLY IN EASTERN WASHINGTON, SINCE THE WHOLESAL COST OF PAM IS ABOUT \$4.00 PER POUND, THIS IS AN EXTREMELY COST-EFFECTIVE DUST CONTROL METHOD.

TECHNIQUES THAT CAN BE USED FOR UNPAVED ROADS AND LOTS INCLUDE:

LOWER SPEED LIMITS. HIGH VEHICLE SPEEDS INCREASES THE AMOUNT OF DUST STIRRED UP FROM UNPAVED ROADS AND LOTS.

UPGRADE ROAD SURFACE STRENGTH BY IMPROVING PARTICLE SIZE, SHAPE, AND MINERAL TYPES THAT MAKE UP THE SURFACE AND BASE MATERIALS.

ADD SURFACE GRAVEL TO REDUCE THE SOURCE OF DUST EMISSION. LIMIT THE AMOUNT OF FINE PARTICLES (THOSE SMALLER THAN .075 MILLIMETERS) 10 TO 20 PERCENT.

USE GEOTEXTILE FABRIC TO INCREASE THE STRENGTH OF NEW ROADS OR ROADS UNDERGOING RECONSTRUCTION.

ENCOURAGE THE USE OF ALTERNATE, PAVED ROUTES, IF AVAILABLE.

RESTRICT USE BY TRACKED VEHICLES AND HEAVY TRUCKS TO PREVENT DAMAGE TO ROAD SURFACE AND BASE.

APPLY CHEMICAL DUST SUPPRESSANTS USING THE ADMX METHOD, BLENDING THE PRODUCT WITH THE TOP FEW INCHES OF MATERIAL. SUPPRESSANTS MAY ALSO BE APPLIED AS SURFACE TREATMENTS.

PAVE UNPAVED PERMANENT ROADS AND OTHER TRAFFICKED AREAS.

USE VACUUM STREET SWEEPERS.

REMOVED MUD AND OTHER DIRT PROMPTLY SO IT DOES NOT DRY AND THEN TURN INTO DUST.

LIMIT DUST-CAUSEING WORK ON WINDY DAYS.

MAINTENANCE STANDARDS: REPAV AREA AS NECESSARY TO KEEP DUST TO A MINIMUM. WATER APPLIED TO CONSTRUCTION SITES FOR DUST CONTROL MUST NOT LEAVE THE SITE AS SURFACE RUNOFF.

BMP C151: CONCRETE HANDLING

INFORMATION TAKEN FROM CHAPTER 7 OF THE EASTERN WASHINGTON STORMWATER MANAGEMENT MANUAL 2004 EDITION

PURPOSE: CONCRETE WORK CAN GENERATE PROCESS WATER AND SLURRY THAT CONTAIN FINE PARTICLES AND HIGH PH, BOTH OF WHICH CAN VIOLATE WATER QUALITY STANDARDS IN THE RECEIVING WATER. THIS BMP IS INTENDED TO MINIMIZE AND ELIMINATE CONCRETE PROCESS WATER AND SLURRY FROM ENTERING WATERS OF THE STATE.

CONDITIONS OF USE: ANY TIME CONCRETE IS USED, THESE MANAGEMENT PRACTICES SHALL BE UTILIZED. CONCRETE CONSTRUCTION PROJECTS INCLUDE, BUT ARE NOT LIMITED TO, THE FOLLOWING:

- CURBS
- SIDEWALKS
- ROADS
- BRIDGES
- FOUNDATIONS
- FLOORS
- RUNWAYS

DESIGN AND INSTALLATION: CONCRETE TRUCK CHUTES, PUMPS, AND INTERNALS SHALL BE WASHED OUT ONLY INTO FORMED AREAS AWAITING INSTALLATION OF CONCRETE OR ASPHALT.

UNUSED CONCRETE REMAINING IN THE TRUCK AND PUMP SHALL BE RETURNED TO THE ORIGINATING BATCH PLANT FOR RECYCLING.

HAND TOOLS INCLUDING, BUT NOT LIMITED TO, SCREEDS, SHOVELS, RAKES, FLOATS, AND TROWELS SHALL BE WASHED OFF ONLY INTO FORMED AREAS AWAITING INSTALLATION OF CONCRETE OR ASPHALT.

EQUIPMENT THAT CANNOT BE EASILY MOVED, SUCH AS CONCRETE PAVERS, SHALL ONLY BE WASHED IN AREAS THAT DO NOT DIRECTLY DRAIN TO NATURAL OR CONSTRUCTED STORMWATER CONVEYANCES.


WASHDOWN FROM AREAS SUCH AS CONCRETE AGGREGATE DRIVEWAYS SHALL NOT DRAIN DIRECTLY TO NATURAL OR CONSTRUCTED STORMWATER CONVEYANCES.

WHEN NO FORMED AREAS ARE AVAILABLE, WASHWATER AND LEFTOVER PRODUCT SHALL BE CONTAINED IN A LINED CONTAINER. CONTAINED CONCRETE SHALL BE DISPOSED OF IN A MANNER THAT DOES NOT VIOLATE GROUNDWATER OR SURFACE WATER QUALITY STANDARDS.

MAINTENANCE STANDARDS: CONTAINERS SHALL BE CHECKED FOR HOLES IN THE LINER DAILY DURING CONCRETE POURS AND REPAIRED THE SAME DAY.


CONCRETE TRUCK WASHOUT STANDARDS

NOT TO SCALE



GRAVEL AND WIRE MESH INLET SEDIMENT FILTER

NOT TO SCALE



* GRAVEL SHALL BE 2"-3" CLEAN STONE

SPECIFIC APPLICATION

THIS METHOD OF INLET PROTECTION IS APPLICABLE WHERE HEAVY CONCENTRATED FLOWS ARE EXPECTED, BUT NOT WHERE PONDING AROUND THE STRUCTURE MIGHT CAUSE EXCESSIVE INCONVENIENCE OR DAMAGE TO ADJACENT STRUCTURES AND UNPROTECTED ACRES.

PLANS NOT APPROVED BY AGENCY

Spokane County Permit No.:

Floodplain-Grading-

City of Spokane Valley Permit No.:

SUB-2015-0001
 FPD-2016-
 EGR-201X-XXXX

WOOD R. WHIPPLE
 STATE OF WASHINGTON
 125482
 REGISTERED PROFESSIONAL ENGINEER
 10/13/16

SHEET C9.3

JOB NUMBER
13-1166

SCALE:		PROJ #: 13-1166	<input checked="" type="checkbox"/> CIVIL <input type="checkbox"/> STRUCTURAL <input type="checkbox"/> SURVEYING <input type="checkbox"/> TRAFFIC <input type="checkbox"/> PLANNING <input type="checkbox"/> LANDSCAPE <input type="checkbox"/> OTHER										
HORIZONTAL: N/A		DATE: 08/03/16											
VERTICAL: N/A		DRAWN: RMA REVIEWED: TRW											
<div style="display: flex; justify-content: space-between;"> <div> <p>NAV D - 88</p> <p>TBM S-5 OF THE SOUTH PONDEROSA SEWER PROJECT WITH AN ELEVATION OF 2005.87 (NAV D29) - 2009.67 (NAV D88) WAS USED FOR THE VERTICAL DATUM FOR THIS MAP.</p> </div> <div style="text-align: center;"> </div> <div> <p>GUSTIN DITCH IMPROVEMENT PLANS</p> <p>SWPPP BMPs</p> <p>40TH AVENUE</p> <p>SPOKANE COUNTY, WA</p> </div> </div>													
<table border="1"> <tr> <th>NO.</th> <th>DATE</th> <th>BY</th> <th>ORIGINAL PREPARATION</th> <th>REVISIONS</th> </tr> <tr> <td>A</td> <td>08/03/16</td> <td>RMA</td> <td></td> <td></td> </tr> </table>		NO.	DATE	BY	ORIGINAL PREPARATION	REVISIONS	A	08/03/16	RMA				
NO.	DATE	BY	ORIGINAL PREPARATION	REVISIONS									
A	08/03/16	RMA											

PA\WCE_WORK\2013 WCE PROJECTS\2013-1166 Walker - Painted Hills GC\DWG\GUSTIN-C9.0 EROSION CONTROL.dwg, 10/13/2016 1:45:37 PM